



Ref. Certif. No.

JPTUV-134470-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Uninterruptible Power Supply
Name and address of the applicant	American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan
Name and address of the manufacturer	American Power Conversion Holdings Inc., Taiwan Branch 5F., No.189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan
Name and address of the factory	See additional page(s)
Ratings and principal characteristics	i/p: 1) AC 220-240V or AC 230V; 8A; 50/60Hz; 1Ø; 2)-3) AC 220-240V; 10A; 50/60Hz; 1Ø; Class I o/p: refer to the test report.
Trademark (if any)	APC
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1) BR900GXYYYYYY (X=I, -FR or -GR; Y=any alphanumeric, +, *, #, _ , - or blank) 2) BR1300MI 3) BR1600MI
Additional information (if necessary may also be reported on page 2)	For model differences, refer to the test report. Re-issue of JPTUV-134470 dated 2022-04-25, due to non-technical change.
A sample of the product was tested and found to be in conformity with	IEC 62040-1:2017+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN22883L 002

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.  
Global Technology Assessment Center  
4-25-2 Kita-Yamata, Tsuzuki-ku  
Yokohama 224-0021, Japan  
Phone + 81 45 914-3888  
Fax + 81 45 914-3354  
Mail: info@jpn.tuv.com  
Web : www.tuv.com

Date: 2023-10-17

Signature:

Dennis Chiu