

# CERTIFICATION

<b>Applicant</b>	: American Power Conversion Holdings Inc. Taiwan Branch
<b>Address</b>	: 5F, No. 189, Sec 2, Jiuzong Rd., Neihu Dist., Taipei, Taiwan
<b>Manufacturer</b>	: American Power Conversion Holdings Inc. Taiwan Branch
<b>Address</b>	: 5F, No. 189, Sec 2, Jiuzong Rd., Neihu Dist., Taipei, Taiwan
<b>Description of EUT</b>	: UPS
<b>Trade Name</b>	: APC by Schneider-Electric
<b>Model Number</b>	: BR900MI
<b>Product Series</b>	: BR650MI, BR900MIyyyyyyyyy, BR650MIyyyyyyyyy (y can be any alphanumeric, +, *, #, _, - or blank)
<b>Type of Test</b>	: <b>EMC Directive 2014/30/EU for CE Marking</b>
<b>Technical Standard</b>	: <b>Emission</b>  EN IEC 62040-2:2018 Environment: First / Classification of EUT: Category C1 EN IEC 61000-3-2:2019+A1:2021  <b>Immunity</b>  EN IEC 62040-2:2018 Environment: First / Classification of EUT: Category C1  IEC 61000-4-2:2008 IEC 61000-4-6:2013 IEC 61000-4-3:2020 IEC 61000-4-8:2009 IEC 61000-4-4:2012 IEC 61000-2-2:2002+A1:2017+A2:2018 IEC 61000-4-5:2017
<b>Report Number</b>	: HA220371-CE
<b>Receipt Date</b>	: 19-May-2022
<b>Issued Date</b>	: 24-Jun-2022
<b>Test Result</b>	: <b>Compliance</b>

The above equipment was tested by **HongAn TECHNOLOGY CO., LTD.**, for compliance with the requirement set forth in EMC Directive 2014/30/EU and the technical standards mentioned above.

1. The results of the test report relate only to the sample tested.
2. The test report shall not be reproduced without the written approval of **HongAn TECHNOLOGY CO., LTD.**

C E



**HongAn TECHNOLOGY EMC Laboratory**

LINKOU DIST, NEW TAIPEI CITY, TAIWAN, R.O.C.

**FAX :** +886-2-26019259

**E-mail :** [hatlab@ms19.hinet.net](mailto:hatlab@ms19.hinet.net)