

**IECEE**

TM

Ref. Certif. No.

JPTUV-133793-A1/M1

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Uninterruptible Power Supply

Name and address of the applicant

American Power Conversion Holdings Inc., Taiwan Branch  
5F., No. 189, Sec. 2, Jiuzong Rd.,  
Neihu Dist., Taipei City 11494 Taiwan

Name and address of the manufacturer

American Power Conversion Holdings Inc., Taiwan Branch  
5F., No. 189, Sec. 2, Jiuzong Rd.,  
Neihu Dist., Taipei City 11494 Taiwan

Name and address of the factory

See additional page(s)

Ratings and principal characteristics

i/p: 1) AC 230V or AC 220-240V; 6.0A; 50/60Hz; 1Ø;  
2), 3) AC 220-240V; 2) 3.2A; 3) 4.3A; 50/60Hz; 1Ø;  
Class I  
o/p: refer to the test report.

Trademark (if any)

APC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) BR550GXXXXXX, 2) BR650MXXXXXX, 3) BR900MXXXXXX  
(X = I or hyphen; Y = any alphanumeric, +, \*, #, \_, hyphen  
or blank)Additional information (if necessary may  
also be reported on page 2)For model differences, refer to the test report.  
Re-issue of JPTUV-133793-M1 dated 2022-05-25,  
due to non-technical change.A sample of the product was tested and  
found to be in conformity with

IEC 62040-1:2017+A1

As shown in the Test Report Ref. No. which  
forms part of this Certificate

CN21KH8H 003

This CB Test Certificate is issued by the National Certification Body

**TÜVRheinland®**TÜV Rheinland Japan Ltd.  
Global Technology Assessment Center  
4-25-2 Kita-Yamata, Tsuzuki-ku  
Yokohama 224-0021, Japan  
Phone + 81 45 914-3888  
Fax + 81 45 914-3354  
Mail: info@jpn.tuv.com  
Web : www.tuv.com

Date: 2023-10-17

Signature:

Dennis Chiu