


VIEW-A (DISPLAY INTERFACE-ENLARGED VIEW)




NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR
- TO INSTALLATION AND SITE PREPARATION WORK
- 3. ALL DIMENSIONS ARE IN INCHES [MILLIMETERS]
- 4. NET WEIGHT OF UNIT IS 22.8 lb [10.34kg].
 5. LENGTH OF INPUT CORD IS 120 Inches [3048mm].
- 6. UNIVERSAL MOUNTING BRACKET IS AN ALTERNATIVE MOUNTING METHOD
- TO THE TOOL LESS MOUNT FOR NON APC RACKS.
- 7. BRACKET KITS TO MOUNT TO SPECIFIC COMPETITORS RACKS ARE AVAILABLE AS OPTIONS.

SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric

TLE:	ZERO U, 14.4kW, 208V				DWG NO: AP7899B			REV.
					DRAWN BY:	Jayaprakash	03-DEC-20	THIRD
					ENGINEER:	Katie Burke	03-DEC-20	ANGLE
OJEC	T:SUBMITTAL DRA	AWINGS	SHEET	1 0F 2	APPROVED BY:	Katie Burke	03-DEC-20	PROJECTION



MOLE 2

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR
 TO INSTALLATION AND PREPARATION WORK.
- 3. THIS DRAWING DEPICTS THE POWER SYSTEM CONNECTIONS AND IS NOT REPRESENTATIVE OF THE PHYSICAL LAYOUT. PLEASE REFER TO MECHANICAL DRAWINGS FOR PHYSICAL LAYOUT.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE:	RACK PDU, METERED,
	ZERO U, 14.4kW, 208V
	INPUT: CS8365L, 10ft CORD
	OUTPUT: (24)C13, (4)C19, (2)L6-30F
	ELECTRICAL SCHEMATIC

PROJECT: SUBMITTAL DRAWING SHEET 2 OF 2

DWG NO:	P78	99B	REV.
DRAWN BY:	Jayaprakash	03-DEC-20	ANGLE
ENGINEER:	Katie Burke	03-DEC-20	PROJECTION
APPROVED BY:	Katie Burke	03-DEC-20	N.A