

- NOTES:


 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES]


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider **Electric**

	TITLE:	MICRO	DC 24U	SX	
1	SHOCK	3KV. PACKAGING	A, 120V & UNLO	ADING	DETAILS

MICRO DC 24U SX 3KVA. 120V	MDC24SX3KVAT REV.			
SHOCK PACKAGING & UNLOADING DETAILS	DRAWN BY: JAYAPRAKASH	08-MAY-17	FIRST	
	ENGINEER: G IVEY	11-MAY-17	ANGLE	
PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 6	APPROVED BY: T HORSTMANN	11-MAY-17	PROJECTION	





- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].


NOTES:


1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE
OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER
ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE:	MICRO DC 24U SX 3KVA, 120V UNLOADING DETAILS	
--------	--	--

	-		DWG NO: MDC24SX3KVAT REV.			REV.
1			DRAWN BY:	JAYAPRAKASH	08-MAY-17	FIRST
:			ENGINEER:	G IVEY	11-MAY-17	ANGLE
	PROJECT: SUBMITTAL DRAWINGS	SHEET 2 OF 6	APPROVED BY:	T HORSTMANN	11-MAY-17	PROJECTION





Sl.No	Part Number	Description	Quantity	Configuration
1	NBHN125	NetBotz 125 kHz Handle Kit	1	Installed
2	NBRK0250	NetBotz Rack Monitor 250	1	Installed
3	NBES0303	NetBotz Door Switch Sensors (2) for an APC Rack - 12 ft.	1	Installed
4	AP9891	Power Cord Kit (5 ea), C13 to 5-15P, 0.6m	1	Accessory Box
5	AR8136BLK	APC 1U 19" Black Modular Toolless Blanking Panel - Qty 10	1	Accessory Box
6	AR8429	Horizontal Cable Organizer 1U w/brush strip	1	Installed
7	AP7902B	Rack PDU, Switched, 2U, 30A, 120V, (16)5-20	2	Installed
8	SMX3000RMLV2UNC	APC Smart-UPS X 3000VA Rack/Tower LCD 100-127V with Network Card	2	Installed
9	AR3104SP1	NetShelter SX 24U 600mm Wide x 1070mm Deep Enclosure - 1250 lbs. Shock Packaging	1	Installed


NOTES

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- 4. NET WEIGHT OF UNIT WITHOUT UPS AND ACCESSORIES IS 89.09Kg [196 lb].
- 5. CABLE ENTRY IS TOP OR BOTTOM OF THE UNIT.
- 6. FRONT AND REAR SERVICE ACCESS REQUIRED.
- AIR FLOW AND SERVICE REQUIREMENTS, AS WELL AS MINIMUM CLEARANCE TO FIRE SUPPRESSION SYSTEMS SHOULD BE CONSIDERED WHEN LOCATING THE ENCLOSURE.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: MICRO DC 24U SX 3KVA, 120V	DWG NO: MDC24SX3KVAT REV.		
GENERAL ARRANGEMENT	DRAWN BY: JAYAPRAKASH	08-MAY-17	FIRST
	ENGINEER: G IVEY	11-MAY-17	ANGLE
PROJECT: SUBMITTAL DRAWINGS SHEET 3 OF 6	APPROVED BY: T HORSTMANN	11-MAY-17	PROJECTION




- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE


Schneider **Electric**

TITLE:	MICRO DC 24U SX 3KVA, 120V TOP & BOTTOM VIEWS

DRAWN BY: JAYAPRAKASH 08-MAY-17 FIRST ANGLE ENGINEER: G IVEY 11-MAY-17 PROJECT: SUBMITTAL DRAWINGS SHEET 4 OF 6 APPROVED BY: T HORSTMANN 11-MAY-17 PROJECTION







NOTES:


- INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS
 PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



MICRO DC 24U S 3KVA, 12OV TYPICAL ARRANGEMENT-INT	
PROJECT: SUBMITTAL DRAWINGS	SHEET 5 OF 6

DWG NO: MDC	224S>	(3KVAT	REV.
	YAPRAKASH	08-MAY-17	FIRS
ENGINEER:	G IVEY	11-MAY-17	ANGL
APPROVED BY: T I	HORSTMANN	11-MAY-17	PROJECTIO



ISOMETRIC VIEW (INTERNAL)

NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



MICRO DC 24U SX 3KVA, 120V			DWG NO: MDC24SX3KVAT		
TYPICAL ARRANGEMENT ISOMETRIC VIEW		DRAWN BY:	JAYAPRAKASH	08-MAY-17	
			ENGINEER:	G IVEY	11-MAY-17
	PROJECT: SUBMITTAL DRAWINGS SHEET 6	6 OF 6	APPROVED BY:	T HORSTMANN	11-MAY-17

FIRST ANGLE

PROJECTION