


**TALL FRAME-SINGLE POD-DUCTED CEILING WITHOUT RACKS AND DISTRIBUTION PANEL**



**FRONT VIEW**

**NOTES:**

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
4. WEIGHT - REFER TO THE RESPECTIVE SUBMITTALS.
- △5. THIS DIMENSION MAY VARY AS PER RACK WIDTH AND NUMBER OF RACK. SHOWN TYPICAL ARRANGEMENT FOR TWELVE 600mm WIDE RACKS. TELESCOPING BEAM CAN ACCOMMODATE ANY COMBINATION OF RACKS FROM 8-12 FEET.
- △6. TALL FRAME CAN ACCOMMODATE UP TO 52U, SHOWN TYPICAL ARRANGEMENT FOR 42U/48U RACKS. REFER TO TABLE FOR DETAILS.
7. THIS DRAWING IS FOR TYPICAL CONFIGURATION.


RACK HEIGHT	
U	mm [inch]
42U	1991 [78.39]
45U	2124 [83.64]
48U	2258 [88.90]

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: HYPERPOD TALL FRAME, SINGLE POD, DUCT RISER WITHOUT RACK AND DISTRIBUTION PANEL FRONT VIEW  
 PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 3

DWG NO: TFSPDRWORD REV. 0  
 DRAWN BY: JAYAPRAKASH 04-MAY-17 FIRST ANGLE  
 ENGINEER: A COTTER 12-MAY-17 PROJ  
 APPROVED BY: SYMONS 12-MAY-17



**NOTES:**

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- △ 4. OVER ALL CONTAINMENT POD WIDTH DIMENSION MAY VARY AS PER THE COMPONENT SELECTED, BASED ON THE DEPTH OF THE RACK. REFER TO TABLE FOR DETAILS.
- △ 5. RACK AND ROOF HEIGHT VARY AS PER THE COMPONENT SELECTED.
6. THIS DRAWING IS FOR TYPICAL CONFIGURATION.

△ 4

RACK DEPTH
mm [inch]
825 [32.480]
1070 [42.125]
1200 [47.244]


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: HYPERPOD TALL FRAME, SINGLE POD, DUCT RISER WITHOUT RACK AND DISTRIBUTION PANEL RIGHT SIDE VIEW  
 PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF 3

DWG NO: TFSPDRWORD  
 DRAWN BY: JAYAPRAKASH 04-MAY-17  
 ENGINEER: A COTTER 12-MAY-17  
 APPROVED BY: SYMONS 12-MAY-17

REV. 0  
 FIRST ANGLE PROJ



TOP VIEW



AISLE WIDTH	
Feet	mm [inch]
3	914.4 [36.0]
4	1219.2 [48.0]
5	1524.0 [60.0]
6	1828.8 [72.0]

NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- △ 4. ACROSS AISLE DIMENSION MAY VARY AS PER THE REQUIREMENT. TABLE SHOWS STANDARD CONFIGURATION.
5. THIS DRAWING IS FOR TYPICAL CONFIGURATION.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: HYPERPOD TALL FRAME, SINGLE POD, DUCT RISER WITHOUT RACK AND DISTRIBUTION PANEL TOP VIEW

PROJECT: SUBMITTAL DRAWINGS SHEET 3 OF 3

DWG NO:	TFSPDRWORD	REV.	0
DRAWN BY:	JAYAPRAKASH	04-MAY-17	FIRST ANGLE PROJ
ENGINEER:	A COTTER	12-MAY-17	
APPROVED BY:	SYMONS	12-MAY-17	