


# TALL FRAME-DOUBLE POD-DUCTED CEILING WITH RACKS AND DISTRIBUTION PANEL




△6

| RACK HEIGHT | DUCT RISER HEIGHT          |
|-------------|----------------------------|
| U           | mm [inch]                  |
| 42U         | 1991 [78.39] 2757 [108.56] |
| 45U         | 2124 [83.64] 2890 [114.90] |
| 48U         | 2258 [88.90] 3024 [120.16] |

## NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
4. WEIGHT - REFER TO THE RESPECTIVE SUBMITTALS.
- △ 5. THIS DIMENSION MAY VARY AS PER RACK WIDTH AND NUMBER OF RACK. SHOWN TYPICAL ARRANGEMENT FOR TWELVE 600mm WIDE RACKS. TELESCOPING BEAM CAN ACCOMMODATE ANY COMBINATION OF RACKS FROM 8-12 FEET.
- △ 6. TALL FRAME CAN ACCOMMODATE UP TO 52U, SHOWN TYPICAL ARRANGEMENT FOR 42U/48U RACKS. REFER TO TABLE FOR DETAILS.
7. THIS DRAWING IS FOR TYPICAL CONFIGURATION.

△6  
"U" HEIGHT  
MARKER  
(TYP.)



DETAIL-A

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: HYPERPOD  
TALL FRAME, DOUBLE POD, DUCT RISER  
WITH RACK AND DISTRIBUTION PANEL  
FRONT VIEW

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 3


DWG NO: TFDPRWRD REV. 0

DRAWN BY: JAYAPRAKASH 16-MAY-17

ENGINEER: A COTTER 17-MAY-17

APPROVED BY: SYMONS 17-MAY-17

REV. 0  
FIRST  
ANGLE  
PROJ



|               |
|---------------|
| <b>4</b>      |
| RACK DEPTH    |
| mm [inch]     |
| 825 [32.480]  |
| 1070 [42.125] |
| 1200 [47.244] |

**NOTES:**

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
4. OVERALL CONTAINMENT POD WIDTH DIMENSION MAY VARY AS PER THE COMPONENT SELECTED.  
1070 [42.13] DEPTH RACK SHOWN FOR TYPICAL ARRANGEMENT. REFER TO TABLE FOR DETAILS.
5. THIS DIMENSION MAY VARY AS PER THE RACK SELECTED. 48U RACK SHOWN FOR TYPICAL ARRANGEMENT.

**RIGHT SIDE VIEW**

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: HYPERPOD TALL FRAME, DOUBLE POD, DUCT RISER WITH RACK AND DISTRIBUTION PANEL RIGHT SIDE VIEW

PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF 3

DWG NO: TFDPRDRWRD

DRAWN BY: JAYAPRAKASH 16-MAY-17

ENGINEER: A COTTER 17-MAY-17

APPROVED BY: SYMONS 17-MAY-17

REV. 0

FIRST

ANGLE

PROJ



TOP VIEW



| AISLE WIDTH |               |
|-------------|---------------|
| Feet        | mm [inch]     |
| 3           | 914.4 [36.0]  |
| 4           | 1219.2 [48.0] |
| 5           | 1524.0 [60.0] |
| 6           | 1828.8 [72.0] |

**NOTES:**

1. COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- △ 4. ACROSS AISLE DIMENSION MAY VARY AS PER THE REQUIREMENT. TABLE SHOWS STANDARD CONFIGURATION.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: HYPERPOD TALL FRAME, DOUBLE POD, DUCT RISER WITH RACK AND DISTRIBUTION PANEL TOP VIEW  
 PROJECT: SUBMITTAL DRAWINGS SHEET 3 OF 3

|              |             |           |                  |
|--------------|-------------|-----------|------------------|
| DWG NO:      | TFDPDRWRD   | REV.      | 0                |
| DRAWN BY:    | JAYAPRAKASH | 16-MAY-17 | FIRST ANGLE PROJ |
| ENGINEER:    | A COTTER    | 17-MAY-17 |                  |
| APPROVED BY: | SYMONS      | 17-MAY-17 |                  |