



- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. 230V TERMINALS INCLUDED FOR RECEIVER HEATER.
- 4. RECEIVER ACAC75014 (1 NUMBER) SHALL BE ORDERED SEPARATELY AND MOUNTED ON SITE.
- USE 18AWG UNLESS OTHERWISE SPECIFIED.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR JSED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTUR OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



AIR COOLED CONDENSER
CONDENSER 1×1 BUILD TO ORDER,
38kW, 95F, 208-230V, 3PH, 60Hz
WIRING DIAGRAM

ACCD75234 JAYAPRAKASH DRAWN:

14-JUN-17 ANGLE ENGINEER: Nick Schweissguth 14-JUN-17 PROJECTION PROJECT: DRAWINGS SHEET 2 OF 2 APPROVED Nick Schweissguth 14-JUN-17 NA