


- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE



ı	TITLE:
	NetShelter SX 18U
ı	600mm WIDE x 900mm DEEP
ı	SERVER RACK ENCLOSURE WITH SIDE
ı	TOP VIEW & SECTION VIEW
ı	TOP VIEW & SECTION VIEW
ı	

TITLE: NetShelter SX 18U 600mm WIDE x 900mm DEEP	DWG NO: AR3006			REV.		
SERVER RACK ENCLOSURE WITH SIDES	DRAWN BY:	JAYAPRAKASH	17-MAY-19	FIRST		
TOP VIEW & SECTION VIEW	ENGINEER:	Jinxin REN	DD-MMM-YY	ANGLE		
PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF 3	APPROVED BY:	TBD	DD-MMM-YY	PROJECTION		



(WITH PALLET BRACKETS, CAN BE USED FOR ANCHORING) TOP ROOF NOT SHOWN

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.

2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.

3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

4. ANCHORING CAN BE INSTALLED EITHER INSIDE OR OUTSIDE THE NetShelter WITH ONE AT FRONT AND ONE IN BACK. △5. BOLT-DOWN KIT (SKU# AR7701) IS OPTIONAL AND HAS TO BE ORDERED SEPARATELY.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE



IIILE:

NetShelter SX 18U

600mm WIDE x 900mm DEEP

SERVER RACK ENCLOSURE WITH SIDES
BOTTOM VIEWS & ANCHORING DETAILS

AR3006 FIRST DRAWN BY: JAYAPRAKASH 17-MAY-19 NGINEER: Jinxin REN DD-MMM-YY ANGLE PROJECT: SUBMITTAL DRAWINGS SHEET 3 OF 3 APPROVED BY: TBD DD-MMM-YY