

NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider
Electric

TITLE: EASY UPS 3S / EASY UPS 3S PRO
PARALLEL MAINTENANCE BYPASS PANEL
10-40KVA, 3PH, 400V, UP TO 2 UNITS
ISOMETRIC VIEW

PROJECT: SUBMITTAL DRAWINGS | SHEET 1 OF 3

DWG NO: E3SOPT006


DRAWN: AKSHAY/JAYAPRAKASH 22-NOV-25

ENGINEER: YdPING 22-NOV-25


APPROVED: DAVE DONG 22-NOV-25

REV. 1


FIRST
ANGLE
PROJECTION:




BOTTOM VIEW




FRONT VIEW



TOP VIEW



LEFT SIDE VIEW



REAR VIEW

- NOTES:**
1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
 2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
 3. ALL DIMENSIONS ARE IN MILLIMETERS.
 4. CABLE ENTRY AND OUTGOING IS THROUGH BOTTOM OF UNIT.
 5. FRONT SERVICE ACCESS IS REQUIRED.
 6. NET WEIGHT OF THE UNIT IS 30kg.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider
Electric

TITLE: EASY UPS 3S / EASY UPS 3S PRO
PARALLEL MAINTENANCE BYPASS PANEL
10-40kVA, 3PH, 400V, UP TO 2 UNITS
GENERAL ARRANGEMENT

PROJECT: SUBMITTAL DRAWINGS | SHEET 2 OF 3

DWG NO: E3SOPT006

DRAWN: AKSHAY/JAYAPRAKASH 22-NOV-25


ENGINEER: Yaping 22-NOV-25

APPROVED: DAVE DONG 22-NOV-25

REV. 1

FIRST ANGLE

PROJECTION:




FRONT VIEW
(INTERNAL DETAILS)

SIGNAL CABLE EASY UPS 3S PRO CONNECTIONS

CONNECT SIGNAL CABLES 18AWG (NOT SUPPLIED) BETWEEN THE MAINTENANCE BYPASS SWITCH MBB AND UPS1 UPS2.

MAINTENANCE BYPASS PANEL





NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS.
4. REFER TO WIRING DIAGRAM FOR CONTROL AND COMMUNICATION INTERFACE DETAILS.

SIGNAL CABLE CONNECTIONS FOR EASY 3S

CONNECT SIGNAL CABLES 18AWG (NOT SUPPLIED) BETWEEN THE MAINTENANCE BYPASS SWITCH MBB AND UPS1 UPS2.
USE ONE OF THE TWO METHODS SHOWN BELOW



THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric

TITLE: EASY UPS 3S / EASY UPS 3S PRO
PARALLEL MAINTENANCE BYPASS PANEL
10-40kVA, 3PH, 400V, UP TO 2 UNITS
INTERNAL VIEW AND SIGNAL CABLE CONNECTION

PROJECT: SUBMITTAL DRAWINGS SHEET 3 OF 3

DWG NO: E3SOPT006

DRAWN: AKSHAY/JAYAPRAKASH 22-NOV-25

ENGINEER: Yaping 22-NOV-25

APPROVED: DAVE DONG 22-NOV-25

REV. 1

FIRST

ANGLE

PROJECTION