

JPTUV-133696

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Uninterruptible Power Supply

American Power Conversion Holdings Inc., Taiwan Branch 5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan

American Power Conversion Holdings Inc., Taiwan Branch 5F., No.189, Sec. 2, Jiuzong Rd., Neihu Dist., Taipei City 11494 Taiwan

Ablerex Electronics (Suzhou) Co., Ltd. No. 36 WangWu Road Suzhou City, Jiangsu, P.R. China

Input: AC 220-240V; 7.5A; 50/60Hz; 10; Class I
Output: AC 220-240V; 6.8A; 50/60Hz; 1050W; 1500VA

APC

N/A

SMV1500AIXXXXXXXX, SMV1500CAIXXXXXXXX (X = A-Z, 0-9, - or nil)

For model differences, refer to the test report.

IEC 62040-1:2017 IEC 62040-1:2017+A1 See Test Report for National Differences

CN22CTBM 001

This CB Test Certificate is issued by the National Certification Body



2022-03-30

TÜV Rheinland Japan Ltd. Global Technology Assessment Center

4-25-2 Kita-Yamata, Tsuzuki-ku Yokohama 224-0021, Japan

Phone + 81 45 914-3888 Fax + 81 45 914-3354 Mail: info@jpn.tuv.com Web: www.tuv.com

Signature:

Dennis Chiu

0/061 CB 06/20v9 rk

Date: