



TM

Ref. Certif. No.

JPTUV-133694

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Uninterruptible Power Supply

Name and address of the applicant

American Power Conversion Holdings Inc., Taiwan Branch  
5F., No. 189, Sec. 2, Jiuzong Rd.,  
Neihu Dist., Taipei City 11494 Taiwan

Name and address of the manufacturer

American Power Conversion Holdings Inc., Taiwan Branch  
5F., No. 189, Sec. 2, Jiuzong Rd.,  
Neihu Dist., Taipei City 11494 Taiwan

Name and address of the factory

Ablere Electronics (Suzhou) Co., Ltd.  
No. 36 WangWu Road  
Suzhou City, Jiangsu, P.R. China

Ratings and principal characteristics

Input: AC 220-240V; 1) 14.4A, 2) 9.9A; 50/60Hz; 1Ø; Class I  
Output: refer to the test report.

Trademark (if any)

APC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) SMV3000AIXXXXXXXX, SMV3000CAIXXXXXXXX  
2) SMV2000AIXXXXXXXX, SMV2000CAIXXXXXXXX  
(X = A-Z, 0-9, - or nil)Additional information (if necessary may  
also be reported on page 2)

For model differences, refer to the test report.

A sample of the product was tested and  
found to be in conformity withIEC 62040-1:2017  
IEC 62040-1:2017+A1As shown in the Test Report Ref. No. which  
forms part of this Certificate

CN22INS7 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland Japan Ltd.  
Global Technology Assessment Center  
4-25-2 Kita-Yamata, Tsuzuki-ku  
Yokohama 224-0021, Japan  
Phone + 81 45 914-3888  
Fax + 81 45 914-3354  
Mail: info@jpn.tuv.com  
Web: www.tuv.com

Date: 2022-03-30

Signature:

Dennis Chiu