

# CERTIFICATE OF CONFORMITY

## EC Council Directive 2014/30/EU Electromagnetic Compatibility

Registration No.: NTC1904637EV00

**Applicant** : American Power Conversion Holding Inc., Taiwan Branch  
**Address** : 3F., No.205, Sec. 3, Beixin Rd., Xindian Dist. New Taipei City 231  
Taiwan

**Manufacturer** : American Power Conversion Holding Inc., Taiwan Branch  
**Address** : 3F., No.205, Sec. 3, Beixin Rd., Xindian Dist. New Taipei City 231  
Taiwan

**Factory** : VOLTRONIC POWER TECHNOLOGY CORP.  
**Address** : 1-4F, Building 5, YuSheng Industrial Park, No. 467, Section Xixiang,  
National Highway 107, Xixiang, Bao An District, Shenzhen 518102, P.R.  
China

**E.U.T.** : UPS

**Brand Name** :   
by **Schneider Electric**

**Model No.** : abc1KRlde(a=SRV or SPV, b=nil, c=PM, d=L, e=-AR, -GR, -RS, -SP, -KR, -BR,  
-CN, -AZ or nil; For variables a, b, c, d and e refer to the test report page 8  
for details)  
External battery cabinet : ab36RLBP-9A(a=SRV or SPV, b=nil; For variables  
a and b refer to the test report page 8 for details)

**Test Report No.** : NTC1904637EV00

**Standard** : EN 62040-2: 2006+AC: 2006 / Equate test limit with IEC 62040-2: 2016  
EN 61000-3-2: 2014 / IEC 61000-3-2: 2014  
EN 61000-3-3: 2013 / IEC 61000-3-3: 2013

