

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Multiple portable socket-outlets with SPDs

Name and address of the applicant

American Power Conversion Holdings Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist., 11494 Taipei City
Taiwan

Name and address of the manufacturer

Dongguan Quan Sheng Electric Co., Ltd.
2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan,
Guangdong
China

Name and address of the factory

Dongguan Quan Sheng Electric Co., Ltd.
2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town, 523963 Dongguan,
Guangdong
China*Note: When more than one factory, please report on page 2* [Additional information on page 2](#)

Ratings and principal characteristics

16 A, 220-250 V~, 50/60 Hz, MAX. 2500 W (Limited to 10 A by means of
circuit breaker)

Trademark (if any)

APC or APC by Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PME5-RS, PME5B-RS, PME5-GR, PME5B-GR, PME5-SP, PME5B-SP,
PME5-KR, PME5B-KR, PME5B-TR

Additional information (if necessary may also be reported on page 2)

This CB Test Certificate is an addition to CB NL-59848 with Test Report
Number 4352477.50/51 dated 2019-07-31 due to addition of new model,
updates of Trade Mark and Applicant's name and address. [Additional information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002, IEC 60884-1:2002/AMD1:2006, IEC 60884-1:2002/
AMD2:2013, IEC 60884-2-7:2011, IEC 60884-2-7:2011/AMD1:2013, IEC
61643-11:2011

National differences:

DE, NL

As shown in the Test Report Ref. No. which forms part of this Certificate

4388277.50/51,6050059.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2022-06-29

Signature: Miranda Zhou