

# CERTIFICATE

Issued to:

Applicant:

American Power Conversion Holdings Inc., Taiwan  
Branch  
5F., No. 189, Sec. 2, Jiuzong Rd., Neihu Dist.,  
11494 Taipei City, Taiwan

Licensee:

Dongguan Quan Sheng Electric Co., Ltd.  
2nd Industrial Zone, Ju-Tang, Housha Road, Houjie  
Town,  
523963 Dongguan, Guangdong, China

Product : Multiple portable socket-outlets with SPD(s)  
Trade name(s) : APC or APC by Schneider Electric  
Type(s)/model(s) : PM5-GR, PM5-RS, PM5B-RS, PM5T-GR, PM5V-GR and PM5V-RS

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) IEC 60884-1:2002, IEC 60884-1:2002/A1:2006, IEC 60884-1:2002/A2:2013, IEC 60884-2-7:2011, IEC 60884-2-7:2011/A1:2013, NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019, NEN-IEC 60884-1:2019/A2:2019, DIN VDE 0620-2-1:2016, DIN VDE 0620-2-1:2016/A1:2017, EN 61643-11:2012, EN 61643-11:2012/A11:2018, EN 61643-21:2001, EN 61643-21:2001/A1:2009 and EN 61643-21:2001/A2:2013
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2025917


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 20 January 2022 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-121965

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



M. Triulzi  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

|                       |   |
|-----------------------|---|
| Product               | : Multiple portable socket-outlets with SPD(s)              |
| Trade name(s)         | : APC or APC by Schneider Electric                          |
| Type(s)/model(s)      | : PM5-GR, PM5-RS, PM5B-RS, PM5T-GR, PM5V-GR and PM5V-RS     |
| Rated current         | : 16 A  |
| Rated voltage         | : 250 V~  |
| Rated power           | : MAX. 2500 W (Limited to 10 A by means of circuit breaker) |
| Earthing              | : with side earthing-contacts                               |
| Design                | : non-rewirable, with shutters                              |
| Standard sheet        | : III of NEN 1020   |
| Applied flexible cord | : H05VV-F 3G1,0 mm <sup>2</sup>                             |
| Certification mark    | : complies with the requirements                            |
| Cord termination      | : soldered connection                                       |
| Description           | : body of thermoplastic material                            |

**Product data – type PM5B-RS**

|        |  |
|--------|--|
| Design | : 5-fold, provided with circuit-breaker, two-pole rocker switch and AC Surge Protective Device |
|--------|--|

**Product data – type PM5-GR**

|        |  |
|--------|--|
| Design | : 5-fold, provided with circuit-breaker, two-pole rocker switch and AC Surge Protective Device |
|--------|--|

**Product data – type PM5-RS**

|        |  |
|--------|--|
| Design | : 5-fold, provided with circuit-breaker, two-pole rocker switch and AC Surge Protective Device |
|--------|--|

**Product data – type PM5T-GR**

|        |   |
|--------|---|
| Design | : 5-fold, provided with circuit-breaker, two-pole rocker switch, AC Surge Protective Device and Phone Surge Protective Device |
|--------|---|

**Product data – type PM5V-GR**

|        |  |
|--------|--|
| Design | : 5-fold, provided with circuit-breaker, two-pole rocker switch, AC Surge Protective Device and TV Surge Protective Device |
|--------|--|

**Product data – type PM5V-RS**

|        |  |
|--------|--|
| Design | : 5-fold, provided with circuit-breaker, two-pole rocker switch, AC Surge Protective Device and TV Surge Protective Device |
|--------|--|

**TESTS****Test requirements**

IEC 60884-1:2002  
IEC 60884-1:2002/A1:2006  
IEC 60884-1:2002/A2:2013  
IEC 60884-2-7:2011  
IEC 60884-2-7:2011/A1:2013  
NEN 1020:2019

NEN-IEC 60884-1:2019  
NEN-IEC 60884-1:2019/A1:2019  
NEN-IEC 60884-1:2019/A2:2019  
DIN VDE 0620-2-1:2016  
DIN VDE 0620-2-1:2016/A1:2017  
EN 61643-11:2012  
EN 61643-11:2012/A11:2018  
EN 61643-21:2001  
EN 61643-21:2001/A1:2009  
EN 61643-21:2001/A2:2013

**Test result**

The test results are laid down in DEKRA test file 611076400, 437709300.

**Additional information**

The product also complies with Clause 10.5 of DIN VDE 0620-2-1:2021, BS EN 61643-11:2012 + A11:2018, BS EN 61643-21:2001 + A1:2009 + A2:2013.

Remark: The type nos. PM5.-RS are technically identical to the products PM5.-GR. The last two letters indicate the country code only.

The list of components is laid down in test report 4377093.50/51, 6110764.50/51/52.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

Dongguan Quan Sheng Electric Co., Ltd.  
2nd Industrial Zone, Ju-Tang, Housha Road, Houjie Town,  
523963 Dongguan, Guangdong, China