


TABLE-1

Rating	Number of Additional Power Module(s)
8kVA N+1, Ext. run	ONE
12kVA, Ext. run	ONE
12kVA N+1, Ext. run	TWO
16kVA, Ext. run	TWO
16kVA N+1, Ext. run	THREE



## NOTES:

1. INSTALLATION MUST COMPLY WITH NATIONAL AND LOCAL ELECTRICAL REGULATIONS.
2. PLEASE REFER TO PRODUCT MANUALS FOR DETAILED INFORMATION.
- △ 3. UTILITY SOURCE MUST BE 1PH 220/230/240VAC (1PH+N+G) 50/60Hz OR 3PH 380/400/415VAC(3PH+N+G) 50/60Hz PROVIDED BY OTHERS. NEUTRAL AND GROUND CONTINUITY IS SHOWN ON SHEET 2 OF THIS DRAWING.
- △ 4. DASHED LINES BETWEEN UNITS ( - - - ) REPRESENT CABLING PROVIDED BY OTHERS.
- △ 5. THE SYMMETRA LX, SKU NUMBER SYA8K16IXR, IS SHOWN IN A NON-REDUNDANT CONFIGURATION, HAVING TWO (2) POWER MODULES (SYPM4KI) AND NINE (9) BATTERY MODULES (SYBT5), PROVIDING UP TO 8kVA POWER. FURTHER POWER MODULES (SYPM4KI) CAN BE PURCHASED SEPARATELY AND INSTALLED IN THE SYSTEM, IN ACCORDANCE WITH **TABLE-1**, PROVIDING SALABILITY AND/OR REDUNDANCY. THE RUNTIME CAN ALSO BE FURTHER EXTENDED BY THE PURCHASE AND INSTALLATION OF UP TO FOUR (4) ADDITIONAL BATTERY MODULES (SYBT5) IN THE MAIN UPS FRAME.
- △ 6. UP TO THREE (3), OPTIONAL, SYMMETRA LX PDU PANELS CAN BE PURCHASED SEPARATELY AND INSTALLED TO PROVIDE FURTHER LOAD CONNECTIONS.
7. BLOCKS SHOWN WITH DASHED (-----) LINES REPRESENTS AVAILABLE SPACE/SLOTS FOR ADDITIONAL POWER MODULES AND BATTERY UNITS.
8. UP TO SIX (6) ADDITIONAL EXTENSION BATTERY CABINETS CAN BE CONNECTED TO INCREASE THE RUNTIME FURTHER.
- △ 9. A SMALLER OUTPUT BREAKER MAY BE USED TO ALLOW CIRCUIT BREAKER COORDINATION, HOWEVER THIS MAY REDUCE THE MAXIMUM LOAD KVA SUPPORTED.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

**Schneider Electric**

TITLE: SYMMETRA LX 8kVA TOWER, XR  
INPUT: 220/230/240VAC (1φ+N+G) 50/60Hz  
OR 380/400/415VAC (3φ+N+G) 50/60Hz  
OUTPUT: 220/230/240VAC 50/60Hz  
SYSTEM SINGLE-LINE DIAGRAM

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 2

DWG NO: SYA8K16IXR-SD

DRAWN: S CUNHA 13-JAN-11


ENGINEER: K WHITE 13-JAN-11

APPROVED: N WHITING 13-JAN-11

REV. 2

PROJ. ANGLE

N/A



#### NOTES:

- △1. ONE OR MORE PHASE CONNECTIONS DEPENDING ON MODEL.
- △2. INPUT AND OUTPUT NEUTRAL ARE PERMANENTLY CONNECTED.
- △3. INPUT AND OUTPUT GROUND ARE PERMANENTLY CONNECTED.
4. EQUIPMENT IS NOT CONSIDERED A SEPARATELY DERIVED SYSTEM.  
(REF NEC 2008 ARTICLE 250.20.(D))

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

**Schneider**  
**Electric**

TITLE: SYMMETRA LX 8KVA TOWER, XR  
INPUT: 220/230/240VAC (1φ+N+G) 50/60Hz  
OR 380/400/415VAC (3φ+N+G) 50/60Hz  
OUTPUT: 220/230/240VAC 50/60Hz  
NEUTRAL AND GROUND CONTINUITY

PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF 2

DWG NO: SYA8K16IXR-SD

DRAWN: S CUNHA 13-JAN-11

ENGINEER: K WHITE 13-JAN-11

APPROVED: N WHITING 13-JAN-11

REV. 0

PROJ. ANGLE

N/A