

Certificate of Conformity

issued by Curtis-Straus

Company: APC Corporation NPS Division
Product Tested: SURT7500XLI, SURT7500XLT, SURT7500XLJ,
SURT7500XLTW, SURT10000XLI, SURT10000XLT,
SURT10000XLJ, SURT10000XLTW and SURT192XLBP

Additional Information: APC Part spec IBM Marketing name IBM MTM IBM Option No.
IBM7500RTH6U IBM UPS 7500XHV 2130-6RX 25R5583
IBM10000RTH6U IBM UPS 10000XHV 2130-8RX 25R5584

APC Part spec EMC Marketing name
EMCRT7500XLU NAS-UPS 078-000-039

Original SKU	APC SKU	SKU's	IBM Model	IBM Option #
IBM7500RTH6U	SURT7500XLI	IBMR7500RTH6U	2130-3RX	39Y8842
IBM10000RTH6U	SURT10000XLI	IBMR10000RTH6U	2130-4RX	39Y8853
IBM192RTBP3U	SURT192XLBP	IBMR192RTBP3U	39Y8857	39Y8857
IBM7500RTHJ6U	SURT7500XLJ	IBMR7500RTHJ6U	2130-3JX	40Y9778
IBM10000RTHJ6U	SURT10000XLJ	IBMR10000RTHJ6U	2130-4JX	40Y9780
IBM192RTBPJ3U	SURT192XLBPJ	IBMR192RTBPJ3U	40Y9783	40Y9783

Testing Date: April 24, 25, 28-30, May 1, 2, 5, 2003

Report No.: ED0246-1 Issue 5

A sample of the product as configured in the accompanying test report has been found to comply with the following standards:

EMC Emissions:

- FCC 47 CFR Part 15 Class A emissions requirements (USA)
- EN 55022:1998 Class A ITE emissions requirements (EU)
- EN61000-3-2:1995/A14:2000 Limits for harmonic current emissions
- EN61000-3-3:1995 Limitation of voltage fluctuations and flicker in low-voltage supply systems for equipment with rated current up to and including 16 A

EMC Emissions and Immunity:

- EN50091-2:96 EMC Requirements for Uninterruptable Power Supplies


EMC Immunity:

- EN 55024:1998/A1:2001 Information technology equipment - immunity characteristics for the following standards:

Attested to by the hands and seals:

For Curtis-Straus

For the Manufacturer or Importer

 6/21/06
Test Engineer Date

Date

 6/21/06
EMC Manager Date

Date