



The Compliance Management Group

Issues

A CERTIFICATE OF TEST:

To

*APC
85 Rangeway Road
Bldg. #2
Billerica, MA 01862-0318*

For

**Product: Uninterruptible Power Supply
Model: SUA750I, IBMR750I (MTM# 2130-R2X, Option# 39Y8874)**

Date: December 13, 2007

The Compliance Management Group, a U.S. and internationally approved test laboratory, attests that compliance testing was completed satisfactorily on the aforementioned equipment as specified by the manufacturer and reported in test report number: Q03594. The Compliance Management Group acknowledges that the Equipment Under Test was found to have passed the following standards:

EN50091-2, Uninterruptible Power Systems (UPS) – Part 2: EMC Requirements

EN61000-4-1, 1994, Testing & Measurement Techniques

EN61000-4-2, Electrostatic Discharge

EN61000-4-3, Radiated Electromagnetic Fields

EN61000-4-4, Electrical Fast Transient/Burst

EN61000-4-5, Surge Immunity Requirements

EN61000-4-6, Conducted Disturbances Induced By Radio-Frequency Fields

EN61000-4-8, Power Frequency Magnetic Field Immunity Test

EN61000-4-11, Voltage Dips, Short Interruptions & Voltage Variations Immunity Tests

IEC 1000-2-2, Compatibility Levels For Low-Frequency Conducted Disturbances & Signaling In Public Low-Voltage Supply Systems