



***The Compliance Management Group***

*Issues*

**A CERTIFICATE OF TEST:**

**To**

**APC  
85 Rangeway Road  
Bldg. #2  
Billerica, MA 01862-0318**

**For**

**Product: Uninterruptible Power Supply  
Model: SUA750I, IBMR750I (MTM# 2130-R2X, Option# 39Y8874)**

**Date: December 13, 2007**

*The Compliance Management Group*, a U.S. and internationally approved test laboratory, attests that compliance testing was completed satisfactorily on the aforementioned equipment as specified by the manufacturer and reported in test report number: Q03595. *The Compliance Management Group* acknowledges that the Equipment Under Test was found to have passed the following standards:

**EN61000-3-2 Limits for Harmonic Current Emissions**

**EN61000-3-3 Limitations of Voltage Fluctuations and Flicker in Low-Voltage Supply**