

NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.


 \triangle 8. REFER TO WARNING LABEL ON REAR OF UNIT FOR SCREW MOUNTING.

- 3. UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN INCHES [MILLIMETERS]
- 4. NET WEIGHT OF UNIT IS 8.98LBS [4.08kG].
- 5. LENGTH OF THE CORD IS 120.00IN [3050MM].
- 6. UNIVERSAL MOUNTING BRACKET IS AN ALTERNATIVE MOUNTING METHOD TO THE TOOLLESS MOUNT FOR 3RD PARTY ENCLOSURES. BRACKET IS PROVIDED WITH THE UNIT. DETAILED INSTALLATION INSTRUCTIONS CAN BE FOUND IN THE PROVIDED MANUAL.
- 7. BRACKET KITS TO MOUNT TO SPECIFIC 3RD PARTY ENCLOSURES ARE AVAILABLE AS OPTIONS.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OF JSED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE


Schneider	''
Electric	

LE: RACK PDU 2G, METERED ZERO U, 15A, 100/120V INPUT: NEMA 5-15P OUTPUT: (10)NEMA 5-15R		DWG NO: AP8831			REV _O
	,	DRAWN BY:	S CUNHA	31-OCT-14	THIRD
MAIN MECHANICAL		ENGINEER: M F	IACCO/L KLEPAL	31-OCT-14	ANGLE
OJECT: STD SUBMITTAL DRAWING	SHEET 1 OF 2	APPROVED BY:	B DUNCAN/J SUN	31-OCT-14	PROJ



NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
- 3. DRAWING DEPICTS POWER SYSTEM CONNECTIONS AND IS NOT REPRESENTATIVE OF PHYSICAL LAYOUT. PLEASE REFER TO MECHANICAL DRAWINGS FOR MORE SPECIFIC PHYSICAL DATA.





TITLE: RACK PDU 2G, METERED ZERO U, 15A, 100/120V		DWG NO:	AP88	331	REV _O
INPUT: NEMA 5-15P OUTPUT: (10)NEMA 5-15R	INPUT: NEMA 5-15P		S CUNHA	31-OCT-14	PROJ
		ENGINEER: N	// FIACCO/L KLEPAL	31-OCT-14	ANGLE
PROJECT: STD SUBMITTAL DRAWING	SHEET 2 OF 2	APPROVED E	Y: B DUNCAN/J SUN	31-OCT-14	N/A