



TM

Ref. Certif. No.

JPTUV-133703

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible Power Supply

Name and address of the applicant

American Power Conversion Holdings Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd.,
Neihu Dist., Taipei City 11494 Taiwan

Name and address of the manufacturer

American Power Conversion Holdings Inc., Taiwan Branch
5F., No. 189, Sec. 2, Jiuzong Rd.,
Neihu Dist., Taipei City 11494 Taiwan

Name and address of the factory

See additional page(s)

Ratings and principal characteristics

Input: AC 220-240V; 50/60Hz; 2.7A; 1Ø; Class I
Output: AC 220-240V; 50/60Hz; 2.27A; 500VA; 400W; 1Ø
Icc:1kA

Trademark (if any)

APC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SCL500RMI1UNC, SCL500RMI1UC, SCL500RMI1U

Additional information (if necessary may
also be reported on page 2)

For model differences, refer to the test report.

A sample of the product was tested and
found to be in conformity withIEC 62040-1:2017
IEC 62040-1:2017+A1
See Test Report for National DifferencesAs shown in the Test Report Ref. No. which
forms part of this Certificate

CN22SMBU 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web : www.tuv.com

Date: 2022-04-14

Signature:

Dipl.-Ing. Th. Illing