

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible Power Supply (UPS)

Name and address of the applicant

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street
ANDOVER MA 01810-1067
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street
ANDOVER MA 01810-1067
UNITED STATES OF AMERICA

Name and address of the factory

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 3, Block 14, Phase III, PEZA, 4106 ROSARIO, CAVITE
PHILIPPINES

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Additional Information on page 2

Input: 220-240Vac and 208-240Vac, max. 16A, 50/60Hz
Output: 220-240Vac, max. 3000 VA, max. 2700 W
(see model matrix in test report)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 1

Model / Type Ref.

Smart-UPS, SRT-series
see test report for details

Additional information (if necessary may also be reported on page 2)

Ambient: 40 °C
Date of Origin: 2014-07-24
Reason for M3: model addition

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1(ed.1);am1

As shown in the Test Report Ref. No. which forms part of this Certificate

239974-CI3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2017-11-29

Signature:

A. Fabian



Ref. Certif. No.

DE1-54209/M3/A1

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 10, Block 16, Phase IV,, 4106 PEZA, ROSARIO,
CAVITE
PHILIPPINES

Additional information (if necessary)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2017-11-29

Signature:

A. Fabian