

Certificate of Compliance

Test Sample Name: Network Management Card (NMC)
Model Number: AP9640, AP9641, AP9649
Serial Number: Various 10001-000001

Manufacturer: Schneider-Electric

Tested For: Schneider-Electric
Address: 800 Federal Street
Andover, MA 01810

Contact Person: Vincent Hawxhurst
Phone Number: 978-257-9443

Test Standards:

Radiated Emissions:


- 47 CFR FCC, Part 15 using ANSI C63.4:2014
- EN 61000-6-3:2007+A1:2011
- ICES-003:2017
- VCCI V-3/2015.04
- AS/NZS
- CISPR 32:2015
- EN 61000-3-2 (Harmonics)
- EN 61000-3-3 (Flicker)

Immunity:

- 55024:2010+A1:2016
- CISPR 35:2016
- IEC 62040-2, C2:2016
- EN 61326-2:2013
- EN 61000-4-2 @ ± 2 , ± 4 , ± 6 , ± 8 kV, Direct ± 2 , ± 4 , ± 8 , ± 15 kV Air
- EN 61000-4-3 @ 10V/m
- EN 61000-4-4 @ ± 0.5 , ± 1.0 and ± 2.0 kV (AC Line) & ± 0.5 , ± 1.0 and ± 2.0 kV (I/O cable)
- EN 61000-4-5 @ ± 0.5 kV, ± 1 kV, and ± 2 kV (AC Input) & ± 0.5 kV and ± 1 kV (IO cables)
- EN 61000-4-6 @ 3Vrms (AC Line & I/O cable)
- EN 61000-4-8 @ 30A/m
- EN 61000-4-11

See Test Report number: 2018-168 for details.

Issue Date: December 13, 2018

Authorized Signature: 
Kenneth MacGrath, President
Core Compliance Testing Services, LLC

CORE COMPLIANCE
TESTING SERVICES