


CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



STATEMENT OF TEST RESULTS

STR/2618/IMQ

Product	Circuit-breakers for overcurrent protection for household and similar installations
Tested by request of	SCHNEIDER ELECTRIC INDUSTRIES SAS 31 rue Pierre Mendès France, Eybens F-38050 Grenoble Cedex 9 – France
Manufactured at (name and place)	SCHNEIDER ELECTRIC BULGARIA EOOD Plovdiv plant – 4202 Radinovo – Bulgaria
Preliminary visit carried out by	—
Rating and principal characteristics	1P ($U_e = 230$ V), 1P+N ($U_e = 230$ V), 2P ($U_e = 400$ V), 3P ($U_e = 400$ V), 3P+N ($U_e = 400$ V) or 4P ($U_e = 400$ V) – 50-60 Hz Curve C – $I_n = 6, 10, 16, 20, 25$ or 32 A – $I_{cn} = 6000$ A (see also pages 7 and 9 of Test Report No. PB20-0051970-02-00)
Trade mark (if any)	
Model/Type Ref.	Series Resi9 XP 6000 (see also Additional Sheet and page 9 of Test Report No. PB20-0051970-02-00)
Additional information (if necessary)	—
A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)	
• EN 60898-1:2019	
as shown in the test reports (reference No.)	PB20-0051970-02-00 and from PB20-0051970-02-01 to PB20-0051970-02-18

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

IMQ S.p.A.

Milano, 2020-09-01

Signature of the authorized person _____

Name and function of the authorized person

Mauro Casari

**B.U. "Product Conformity Assessment"
"Project Management & Certification" Area
"Certification" Sector (voluntary field) - Manager**

Tel.: (+39) 02-50731

Fax.: (+39) 02-50991500

e-mail: info@imq.it

20138 MILANO – Via Quintiliano, 43 – ITALY



STATEMENT OF TEST RESULTS

Additional Sheet to STR/2618/IMQ

Description of the generic reference of the circuit-breakers
for overcurrent protection series Resi9 XP 6000

