



BUREAU
VERITAS

Mr. Javier Trillo, Inspector of ECA S.L., of the Bureau Veritas Group, Inspection and Audit Entity, certifies that the electrical cabinets listed below have complied with the requirements of the UNE-EN ISO 9001-2008 standard, and

CERTIFICIES:

At the request of the representative of the company: "SCHNEIDER ELECTRIC INDUSTRIES, SAS" Mr. José Antonio Baño (Responsible for Laboratory and Certifications) and based on the tests carried out by Schneider with supervision of Bureau Veritas, report nº 08 / X52 / 1 / 10108893-1001-1:

The compliance of the THALASSA PLS cabinet with the requirements of the IEC 62208: 2011 standard (ed. 2.0):

PARAGRAPH APH STANDAR D	Description of the section	Code / value tested	Result
9	Type test		
9.3	Marking		Satisfactory
9.4	Static Loads	(A):17,10Kg (B):25,30Kg;(C):50,55Kg	Satisfactory
9.6	Axial loads on metal inserts		Satisfactory
9.7	Degrees of protection against external mechanical impacts.	IK-09	Satisfactory
9.8	Degrees of protection against access to hazardous parts, against ingress of foreign bodies and/or water	IP-66	Satisfactory
9.10	Dielectric strength		Satisfactory
9.13	Resistance to corrosion	Severity test A: interior metal enclosures Severity test A: exterior metal enclosures	Satisfactory

En: Barcelona
Fecha: 24/11/2020

Inspector:
Javier Trillo

BUREAU
VERITAS

Supervisado por:
Sergio Ivan
Departamento INY