



OUTLINE & MOUNTING FOR ASCO® 7000 SERIES FRONT CONNECTED AUTOMATIC TRANSFER & BYPASS-ISOLATION SWITCHES TYPES J7ATB, J7ACTB & J7ADTB RATED 150-600 AMPS










- GENERAL NOTES
- TYPE 1 ENCLOSURES. FREE STANDING. FLOOR MOUNTED. 12 GAUGE FORMED FRAME CONSTRUCTION.
 - NEC STANDARD GAUGE PAN TYPE DOORS WITH LOCKABLE HANDLES AND REMOVABLE COVERS.
 - FINISH: ANSI 61 GRAY, POLYESTER POWDER. UL RECOGNIZED.
 - CONSTRUCTION IS IN ACCORDANCE WITH UL 1008.
 - PADLOCKING PROVISIONS ARE INCLUDED.
ISOLATION HANDLE: THE TRANSFER SWITCH ISOLATION HANDLE MAY BE PADLOCKED WITH THE TRANSFER SWITCH IN THE FULLY ISOLATED (DISCONNECTED POSITION).
 - UNIT CAN BE ADAPTED FOR CONNECTION OF BUS DUCT FLANGES. (CONSULT FACTORY)
 - RECOMMENDED FRONT CLEARANCE: 32 INCHES MINIMUM.
 - A 20% RATED GROUND BUS IS PROVIDED.
 - A FULL RATED NEUTRAL CONNECTION FOR EACH SOURCE AND THE LOAD IS OPTIONAL. WHEN PROVIDED IT IS IN ONE OF THE FOLLOWING FORMATS AS SPECIFIED BY THE CATALOG NO. NEUTRAL TYPE:
TYPE A: SOLID (COPPER BUS) NEUTRAL
TYPE B: SWITCHED NEUTRAL POLE
TYPE C: OVERLAPPING NEUTRAL POLE (NOT AVAILABLE ON 7ADTB & 7ACTB UNITS)

- APPROXIMATE WEIGHT: 950 LBS.
- STANDARD OUTLINE FOR A FOUR POLE 600 AMP TRANSFER SWITCH WITH BYPASS/ISOLATION SWITCH SHOWN. SEE DETAIL "A" FOR LUG CONFIGURATION OF SOLID NEUTRAL.
- IF A PULL BOX IS PROVIDED THE RIGHT SIDE SKINS ARE REMOVED FROM SWITCH ENCLOSURE AND (4) MOUNTING BLOCKS P/N 757047 ARE USED TO CONNECT THE TWO SECTIONS TOGETHER. REFER TO DRAWING 805550 FOR PULL BOX DETAILS. PULL BOX AND SWITCH ENCLOSURE CAN BE SHIPPED AS ONE UNIT OR PULL BOX CAN BE SUPPLIED INDEPENDENTLY.
- BOTH BYPASS SWITCH MANUAL OPERATION HANDLE & TRANSFER SWITCH CARRIAGE MANUAL CRANK HANDLE CAN BE REMOVED. ALSO NOTE THAT THE TRANSFER SWITCH CARRIAGE MANUAL CRANK HANDLE CAN BE LEFT IN PLACE AND FOLDED DOWN.
- CENTER OF GRAVITY.

- CABLING NOTES
- ALL SIZES SUPPLIED STANDARD WITH MECHANICAL (SCREW TYPE) LUGS. (SEE AMP SIZE BELOW)
A. LUG MATERIAL: ALUMINUM ALLOY 6061-T6 WITH ELECTRO TIN PLATED FINISH.
B. SCREW MATERIAL: ALUMINUM ALLOY 6282-T9 WITH ELECTRO TIN PLATED FINISH.
C. UL LISTED, CSA CERTIFIED.
D. LUG MAX WIRE TIGHTENING TORQUE PER UL 486B: SEE TABLE BELOW.
 - OPTIONAL COPPER CRIMP LUGS MAY BE SUPPLIED. CONSULT FACTORY.
A. LUG MATERIAL: HIGH CONDUCTIVITY WROUGHT COPPER FINISH, ELECTRO TIN PLATED.
B. UL LISTED, CSA CERTIFIED.
C. LUG MOUNTING HARDWARE TIGHTENING TORQUE: (REFER TO WITHSTAND CURRENT RATING LABEL PROVIDED ON EACH TRANSFER SWITCH).
D. SUITABLE WIRE BENDING SPACE IS PROVIDED.
 - GROUND LUGS ARE PROVIDED STANDARD AS FOLLOWS:
(6) #4-600MCM AL/CU CABLES FOR 600 AMP
(3) 1/0-250MCM AL/CU CABLES FOR 150-400 AMP.
 - CONSULT FACTORY FOR OTHER TERMINATION REQUIREMENTS.

SIZE	CABLE ACCOMMODATIONS (PER PHASE & NEUTRAL)	LUG TORQUE
150-400	SCREW TYPE (STANDARD)- (2) 1/0 - 250 MCM AL/CU OR	500 IN.-LBS.
	(1) #4 - 600 MCM AL/CU	
600	SCREW TYPE (STANDARD)- (2) #2 - 600 MCM AL/CU	375 IN.-LBS.



PROJECT NAME:		217921 WK BK 04/18/08	
OUTLINE & MOUNTING		SEE ECN	
150-600 AMP TYPE 1 TB/CTB/DTB		210900 [EWM] [EWM] 11/15/08	
FRONT CONNECTED SOFTLOAD BYPASS		ISSUED	
BY DATE	MANUFACTURING TOLERANCES TO BE IN ACCORDANCE WITH ASCO PROCEDURE MP-1-003. FOR PLASTIC PARTS SEE MP-1-005	ASSEMB. REF. NO.	COMPUTER GENERATED DRAWING
CHECKED BY EWM 11/15/08	PROPERTY OF ASCO POWER TECHNOLOGIES. USE PERMITTED FOR OUR WORK ONLY. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.	SCALE 1:1	SIZE DS
TRUSTED APPROVAL	ASCO POWER TECHNOLOGIES, LP. FLORHAM PARK, NEW JERSEY 07932 U.S.A.	802093-005	
FINAL APPROVAL		DRAWING REV. A	ECN NO. 217921