

ATTESTATION OF CONFORMITY

Issued to: Schneider Electric
5 Avenue Raymond Chanas
38320 Eybens
France

For the product: Three phase dry type iron core detuned reactor

Trade name: Schneider Electric

Type/Model: PowerLogic™ PFC

Ratings: 147,6 A, 100 kvar at 400 V

Manufactured by: Licensed Manufacturer of Schneider Electric India Pvt Limited
No: 12A, Hosur Road, Attibele Industrial Area,
Bangalore, Karnataka
India, PIN:562 107

Subject: Measurement of inductance, loss and quality factor, temperature rise test and lightning impulse test

Requirements: The requirements from manufacturer based on IEC 60076-6:2007, Clause 9.10.5, 9.10.6, 9.10.8 and 9.10.9

Remarks: The measurements were conducted at 50 Hz.
A1 version: product name change. Original version issued 25 October 2017.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 2219690.01/A1-INC.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, ? April 2022

Number: 2219690.01/A1-AOC

DEKRA Certification B.V.



F.S. Strikwerda
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed