

ASTA TYPE CERTIFICATE

VERIFICATION OF TEST

Project No: G104719834LCS007 **Certificate No:** ASTA-TYPE-0001276

Applicant: Schneider Electric Private Limited
12A, Hosur Road, Attibele Industrial Area, Neralur Post, Bengaluru (Bangalore)
Urban, Karnataka, 562107

Apparatus: 100kVAr, 400V (U_r), 7%, 50Hz, three-phase, 1.1kV (U_i), dry type iron core detuned reactor

Issued To: Schneider Electric, 5 Avenue Raymond Chanas, 38320 Eybens, France.

Manufactured By: Licenced manufacturer of Schneider Electric Private Limited
Zona Industriale Le Pineta Via Dei Mestieri 10 Castiglione Del Lago Italy 06060

Test Report No: DR20220527-26

Designation: PowerLogic™ PFC Detuned Reactor

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

IEC 60076-6: Edition 1.0 2007-12, Clauses 9.10.5, 9.10.6, 9.10.8, 9.10.9, 9.10.12, IEC 60076-1 Edition 3.0 2011-04 Clause 11.2 and the STL Guide to IEC 60076, Issue 7.0, 18th February 2021, where applicable.

The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.



010

C. Diack-Evans

Certification Engineer
C Diack-Evans

R W Hayward

Certification Officer
R W Hayward

10th August 2022

Date

Project No: G104719834LCS007 **Certificate No:** ASTA-TYPE-0001276

Conditions of use:

ASTA Type Certificates, verification of test is issued by Intertek for the exclusive use of the party applying for the Certificate. Intertek assumes no liability to any parties other than those with which it has an agreement and then only in accordance with the agreed Terms and Conditions.

The Applicant is authorised to copy or distribute Certificates and Test Reports provided the entire contents are included, or Certificate Front Sheets accompanied by any associated pages on which are stated the assigned rated characteristics and no part is obscured or illegible. Permission must be obtained from Intertek before any other kind of reproduction is made.

The holder of a Certificate may claim in Trade Journals, Catalogues, Technical Articles etc., and without the prior approval of Intertek that the product identified in a Certificate is Certified.

To minimise the possibility of any misunderstanding such claims must clearly identify the product(s) certified or approved, the ratings verified and the Standard against which certification/approval has been made.

Any other use of the Intertek or ASTA brand must first be approved in writing by Intertek. Test results and ratings verified by testing included in the Certificate and related Test Reports shall relate specifically to the sample(s) tested.

Authenticity:

Authenticity of any ASTA document can be confirmed by contacting the Intertek ASTA Certification Office at the following address:

Intertek Testing & Certification Ltd., Centre Court, Meridian Business Park, Leicester, LE19 1WD,
United Kingdom. Email: asta@intertek.com

Project No: G104719834LCS007 **Certificate No:** ASTA-TYPE-0001276

Verification of a Dry type iron core detuned reactor

No	Test Performed	Standard	Clause/ Subclause	Verified Tests and Ratings
1	Measurement of winding resistance	IEC 60076-1	11.2	Verified
2	Measurement of inductance	IEC 60076-6	9.10.5	Verified
3	Measurement of loss and quality factor	IEC 60076-6	9.10.6	Verified
4	Temperature rise test	IEC 60076-6	9.10.8	Verified
5	Lightning impulse test	IEC 60076-6	9.10.9	Verified
6	Separate source a.c withstand voltage test	IEC 60076-6	9.10.12	Verified

Project No: G104719834LCS007 **Certificate No:** ASTA-TYPE-0001276

Certificate Contents:

The following documents are attached to and form part of this certificate:

Documents:	Number of pages
Test report no: DR20220527-26 dated 28/07/2022	15
Drawings:	1

Certificate Revision Amendment Table

Certificate Number	Issue Date	Amendment
ASTA-TYPE-0001276	See page 1	Initial issue