

ATTESTATION of conformity with European Directives

Product: Transfer Switching Equipment (Class PC)

Reference TransferPact TA10

Issued to Schneider Electric (China) Co., Ltd. Shanghai Branch.

Address No.669, Suide road, Putuo, Shanghai

Manufacturer Schneider Electric (China) Co., Ltd

Ie: 16A,20A,25A,32A,40A,50A,63A,80A,100A; Ith:100A

Ue: AC220V/230V/240V/250V(2P); AC380V/400V/415V/440V(3P,4P)

Ui:800V, Uimp:6kV

Utilization Category: AC-32B,AC-33B

Technical characteristics Icw: 5kA/100ms, Icm: 15kA

Iq (2P): 25kA(breaker), 80kA(fuse) Iq (3P,4P): 50kA(breaker), 100kA(fuse)

EMC environment: B; Method of controlling: ATSE

Class of equipment: PC; Poles:2P,3P,4P

The submitted sample of the above equipment has been tested for CE marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-6-1:2005+A1:2014	2111996002	2021-08-24

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product The $C \in \mathbb{R}$ marking may be affixed if all relevant and effective European Directives with $C \in \mathbb{R}$ are applicable

Shanghai (P.R. China), November 24th, 2021.

Charlie CHEN Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有

限公司

Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai P.R.C (201612) Tel: +86 21 6195 7000 Fax: +86 21 6195 7001 Email:contact@cn.bureauveritas.com