



BV LCIE  
CHINA  
Number

N°2166AS11SDEC42957

# ATTESTATION of conformity with European Directives

*Product:* **Transfer Switching Equipment (Class PC)**  
*Reference* **TransferPact TA16**  
*Issued to* **Schneider Electric (China) Co., Ltd. Shanghai Branch.**  
*Address* **No.669, Suide road, Putuo, Shanghai**  
*Manufacturer* **Schneider Electric (China) Co., Ltd**



*Technical characteristics* **Ie: 16A,20A,25A,32A,40A,50A,63A,80A,100A,125A,160A; Ith:160A**  
**Ue: AC380V/400V/415V/440V, Ui: 800V, Uimp: 8kV**  
**Utilization Category: AC-33B**  
**Icw:10kA/100ms, Icm: 20kA**  
**Iq:70kA(breaker), 100kA(fuse)**  
**EMC environment: B**  
**Method of controlling: ATSE**  
**Class of equipment: PC**  
**Poles: 3P,4P**

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

**Low Voltage Directive 2014/35/EU**

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
<b>EN 60947-6-1:2005+A1:2014</b>	<b>2111996003</b>	<b>2021-08-24</b>

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), November 24<sup>th</sup>, 2021.

**Charlie CHEN**  
**Product Line Manager**



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)