



E C A

08/EK1/1/6223954-1001-3

Mr. Javier Trillo, Inspector ECA SL, Group Bureau Veritas, Inspection and Auditing Entity certifies that the enclosures listed below have met the requirements of the standard UNE-EN ISO 9001:2008.

## CERTIFIES:

That at the request of the representative of the Company. "SCHNEIDER ELECTRIC INDUSTRIES S.A.S" Ms. Nuria Bas (Project Quality Leader) and Bureau Veritas as third party certification, carried out the inspection of the tests described below on the model enclosures S3HD: NSYS3HD8840 (862x800x430mm) and NSYS3HD10840 (1062x800x430mm).

In accordance with the requirements of the IEC 61439-5:2010, the enclosures SPACIAL S3HD have obtained **SATISFACTORY** results with the documentation submitted to the inspector and based on external inspection that cannot detect hidden failures.

Standard specifications IEC 61439-5:2010

Standard section	Test	Result
10.2.2	Corrosion resistance	SATISFACTORY
10.2.3.101	Dry heat test.	SATISFACTORY
10.2.3.102	Verification flammability.category	SATISFACTORY
10.2.101.1.1	Verification resistance to static charge.	SATISFACTORY
10.2.101.1.2	Verification shock load resistance.	SATISFACTORY
10.2.101.1.3	Verification resistance to torsion.	SATISFACTORY
10.2.101.2.1	Verification of impact resistance - Test applicable for use at room temperatures between 40 and -25 ° C.	Validated by test arctic climate. (10.2.101.2.2)
10.2.101.2.2	Verification of impact resistance - Test applicable for use in arctic climate.	SATISFACTORY
10.2.101.3	Verification of the mechanical strength of doors.	SATISFACTORY
10.2.101.5	Verification of resistance to impacts from sharp objects.	SATISFACTORY

In: Barcelona  
Date: 28/01/2015

Inspector:  
Javier Trillo

Supervised by:  
Ignasi Espadaler  
PC Manager Barcelona