

UK Declaration of Conformity

UK1007321-0

1.0 Product Identification

Object of the declaration: Watt-hour Meter /Energy Meter
 Product: PowerLogic PM3000 Range
 Reference: See models in annex

2.0 This declaration of conformity is issued under the sole responsibility of the manufacturer.

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison, FRANCE

3.0 We Undersigned Schneider Electric Industries SAS declare that Schneider Electric branded products, when subject to correct installation, Maintenance and use confirming their intended purpose, according to applicable regulations and standards in the country where they are installed, to the supplier’s instructions and to accepted rules of the art comply with essential requirements of following Statutory Inventories and is also in conformity with the relevant union harmonization legislation.

4.0

Statutory Inventory with Amendments	Harmonized Standards/Other Technical Specification
SI 2016 No. 1101- Electrical Equipment (Safety) Regulations	BS EN 61010-1:2010+AMD1:2019 BS EN IEC 61010-2-030:2021+A11:2021 BS EN IEC 61557-12:2022+A1:2022
SI 2016 No. 1091- The Electromagnetic Compatibility Regulations	BS EN IEC 61326-1:2021 BS EN 62052-31:2016 BS EN IEC 62052-11:2021 BS EN IEC 62053-21:2021 BS EN IEC 62053-22:2021 BS EN IEC 62053-23: 2003
SI 2012 No 3032 + SI 2012 No. 492- The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012	BS EN IEC 63000:2018

5.0 Signed for on behalf of:
 Place and Date:
 Signature:

Schneider Electric Industries SAS
 Telford, UK, 08.12.2025

Name / Title:

Signed by:

 A578D60923D7459...
David Williams
 VP Marketing UK & Ireland

UK Declaration of Conformity**UK1007321-0****Annex**

Product	Short Description
METSEPM3200	Aux- AC:100-277VLN, DC: 100-300V, Voltage Input- Wye: 60-277VLN; Delta: 100 to 480V L-L, CT operated 1A or 5A nominal, CI 0.5S Energy meter
METSEPM3210	Aux- AC:100-277VLN, DC: 100-300V, Voltage Input- Wye: 60-277VLN; Delta: 100 to 480V L-L, CT operated 1A or 5A nominal, CI 0.5S Energy meter with Pulse output
METSEPM3250	Aux- AC:100-277VLN, DC: 100-300V , Voltage Input- Wye: 60-277VLN; Delta: 100 to 480V L-L, CT operated 1A or 5A nominal, CI 0.5S Energy meter with RS485
METSEPM3255	Aux- AC:100-277VLN, DC: 100-300V , Voltage Input- Wye: 60-277VLN; Delta: 100 to 480V L-L, CT operated 1A or 5A nominal, CI 0.5S Energy meter with RS485,DI &DO .