

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**

CB TEST CERTIFICATE

Product

Service Bypass Unit for UPS

Name and address of the applicant

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street, Andover MA
01810-1067
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street, Andover MA
01810-1067
UNITED STATES OF AMERICA

Name and address of the factory

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 3, Block 14, Phase III, PEZA, 4106 ROSARIO, CAVITE
PHILIPPINES

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Input: 220-240Vac / 380-425 Vac, 50-60Hz, 125A,
Output: 220/230/240Vac, 50/60Hz, 125A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF stage 2

Model / Type Ref.

SRYLSBP20KP

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017
IEC 62040-1:2017/AMD1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

289698-TL4-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2022-10-12

Signature:

T. Baumann