

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible power supply

Name and address of the applicant

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street,
Andover MA 01810-1067
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street,
Andover MA 01810-1067
UNITED STATES OF AMERICA

Name and address of the factory

AMERICAN POWER CONVERSION CORPORATION (A.P.C.)
B.V.
Lot 3, Block 14, Phase III, PEZA, 4106 ROSARIO, CAVITE
PHILIPPINES*Note: When more than one factory, please report on page 2*☒ Additional Information on page 2

Ratings and principal characteristics

For details see page 2.

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Family Name: Symmetra RM (Hydra),
UPS Frame:
SYHF6KI,
Further models see page 2Additional information (if necessary may also
be reported on page 2)☒ Additional Information on page 2A sample of the product was tested and found
to be in conformity withIEC 62040-1:2017
IEC 62040-1:2017/AMD1:2021As shown in the Test Report Ref. No. which
forms part of this Certificate

291524-TL4-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2022-07-19

Signature:



J. Richter

Danam Philippines, Inc
Lot 1-A Block 15, Phase III, 4106 PEZA, Rosario,
Cavite
PHILIPPINES

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 10, Block 16, Phase IV, 4106 PEZA, ROSARIO,
CAVITE
PHILIPPINES

International Precision Assemblies, Inc.
Blk 17, Lot 2 Phase IV, CEPZA Rosario, 4106 Cavite
PHILIPPINES

Additional information (if necessary)

Ratings:

Input: 200-240 VAC, 50-60Hz, 1P+N+PE,
Permanently Connected: 30 A, 5.0 kW,
Output: 200/208/220/230/240 VAC, 50-60Hz,
10A, 2kVA, 1.4 kW (per power module),
30A, 6kVA, 4.2 kW (total output rating)

Further Models:

UPS Assembly:
SYH2K6RMI, SYH4K6RMI, SYH6K6RMI,

XR Frame:

SYRMXR4I

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs



J. Richter

Date: 2022-07-19

Signature: