

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Service Bypass Panel for UPS

Name and address of the applicant

APC by Schneider Electric  
Boston ONE Campus, 800 Federal Street, Andover MA  
01810-1067  
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric  
Boston ONE Campus, 800 Federal Street, Andover MA  
01810-1067  
UNITED STATES OF AMERICA

Name and address of the factory

Schneider Electric IT Business India Pvt Ltd  
IDF 3, No. 73, Survey no. 103,, 2nd Phase, Jigani Industrial  
Area, 562106 BANGALORE  
INDIA*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2Input and output:  
AC 230V or AC 208/220/230/240V, 50/60Hz  
max.10A or16A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SBP1500RMI, SBP3000RMI, SBP3000RMHW

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017  
IEC 62040-1:2017/AMD1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

291527-TL4-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH**VDE** Testing and Certification Institute

Zertifizierungsstelle und internat. Angelegenheiten

Certification Body and internat. Affairs

Date: 2022-08-29

Signature:



A. Fabian