

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product

UPS Accessory - Service Bypass Panel

Name and address of the applicant

APC by Schneider Electric  
Boston ONE Campus, 800 Federal Street,  
Andover MA 01810-1067  
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric  
Boston ONE Campus, 800 Federal Street,  
Andover MA 01810-1067  
UNITED STATES OF AMERICA

Name and address of the factory

Schneider Electric Information Technology (Xiamen) Co.,  
Ltd  
No. 6 Chuangxin Road, Huojuyuan, Torch high-tech Zone,  
361006 Xiamen, Fujian  
CHINA

*Note: When more than one factory, please report on page 2*

Additional Information on page 2

Ratings and principal characteristics

Input: 220-240 V AC, 50-60 Hz,  
Output: 220-240V AC, 50-60 Hz,  
For details see CB test report.

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SBP3000, SBP5000RMI2U (Cord), SBP5000RMI2U (HW),  
SBP6KRMI2U, SBP10KRMI4U, SBP16KRMI4U, SBP16KP

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017  
IEC 62040-1:2017/AMD1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

291525-TL4-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2022-08-11

Signature: B. Megerle