

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible power supply

Name and address of the applicant

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street, Andover MA
01810-1067
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street, Andover MA
01810-1067
UNITED STATES OF AMERICA

Name and address of the factory

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 3, Block 14, Phase III, PEZA, 4106 ROSARIO, CAVITE
PHILIPPINES

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Input: AC 220-240 V, max.16 A, 50/60 Hz
Output: AC 220-240 V, max.9.1 A, 50/60 Hz, max.2000 VA,
1300W, Details see test report

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SUA500PDRI, SUA500PDRI-H, SUA500PDRI-S, DLA750I,
SUA750I, IBM750I, SUA750ICH, SUA750RMI2U,
SMT750RMI2UNC, SMT750I-CH, IBMR750I

Additional information (if necessary may also be reported on page 2)

(see page 2 for further models)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017
IEC 62040-1:2017/AMD1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

294174-TL4-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2022-08-08

Signature:

J. Richter



Ref. Certif. No.

DE1-66520

International Precision Assemblies, Inc.
Blk 17, Lot 2 Phase IV, CEPZA Rosario, 4106 Cavite
PHILIPPINES

Danam Philippines, Inc
Lot 1-A Block 15, Phase III, 4106 PEZA, Rosario,
Cavite
PHILIPPINES

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 10, Block 16, Phase IV., 4106 PEZA, ROSARIO,
CAVITE
PHILIPPINES

Additional information (if necessary)

Model / type ref:

39Y8874, SUA750IX38, SMT750IC, SMT750RMI2UC, DLT750IC, SMC750I-CH, SMT750RMI2U, SMT750I, FJT750I, SMTL750RMI2U, SMTL750RMI2UC, SMTL750RMI2UNC, SUA1000I, SUA1000INBQ, SUA1000RMI2U, SMT1000I, SMT1000RMI2U, SMC1000I, SMC1000I-RS, SMT1000I-CH, SMT1000RMI2UCH, SMC1000I-CH, SMC1000I2U-CH, IBM1000I, IBMR1000I, 39Y8876, SMT1000IC, SMC1000IC, SMT1000RMI2UC, DLT1000IC, DLT1000RMI2UC, SMT1000RMI2UNC, SMTL1000RMI2U, SMTL1000RMI2UC, SMTL1000RMI2UNC, SMC1000I-2U, SMC1000I-2UC, SMC1000I-2URS, SUA1500I, SUA1500INBQ, SUA1500IX114, SUA1500IX38, SUA1500RMI2U, SMT1500I, FJT1500I, SMT1500RMI2U, SMC1500I, SMC1500I-2U, SMT1500I-CH, SMT1500RMI2U-CH, SMC1500ICH, SMC1500I2U-CH, SMT1500IX713, SMT1500RMI2UNC, SMTL1500RMI3UNC, 39Y8883, IBM1500I, IBMR1500I, SMT1500IC, SMC1500IC, SMT1500RMI2UC, SMC1500I-2UC, DLT1500I, DLT1500RMI2U, DLT1500IC, DLT1500RMI2UC, SMTL1500RMI3U, SMTL1500RMI3UC, DLT1500RMI3UC, SMTL1500RMI3UNC, SMC2000I, SMC2000I-2U, SMC2000I-2URS, SMC2000I-RS, SMC2000I-CH, SMC2000I2U-CH

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2022-08-08

Signature:

J. Richter