

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**

CB TEST CERTIFICATE

Product

Uninterruptible power supply

Name and address of the applicant

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street, Andover MA
01810-1067
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street, Andover MA
01810-1067
UNITED STATES OF AMERICA

Name and address of the factory

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 3, Block 14, Phase III, PEZA, 4106 ROSARIO, CAVITE
PHILIPPINES

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

see next page

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SURT20KRMXLI, SURT20KUXI
SURT15KRMXLI, SURT15KUXI

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017
IEC 62040-1:2017/AMD1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

291490-TL4-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2022-04-13

Signature:

M. Ackermann

Danam Philippines, Inc
 Lot 1-A Block 15, Phase III, 4106 PEZA, Rosario,
 Cavite
 PHILIPPINES

AMERICAN POWER CONVERSION CORPORATION
 (A.P.C.) B.V.
 Lot 10, Block 16, Phase IV., 4106 PEZA, ROSARIO,
 CAVITE
 PHILIPPINES

International Precision Assemblies, Inc.
 Blk 17, Lot 2 Phase IV, CEPZA Rosario, 4106 Cavite
 PHILIPPINES

Additional information (if necessary)

Models:

- 1) SURT20KRMXLI, 2) SURT20KUXI
- 3) SURT15KRMXLI, 4) SURT15KUXI

Ratings Input:

AC 220 / 230 / 240 V , 105 A for 1), 2), 83 A for 3),4)
 or AC 380 / 400 / 415 V, 3 W + N + PE, 35 A for 1), 2), 22 A for 3), 4)

Ratings Output:

AC 220 / 230 / 240 V, 16 KW, 20 KVA, 50 - 60 Hz or
 AC 380 / 400 / 415 V, 16 KW, 20 KVA, 50 - 60 Hz
 for 1), 2)
 AC 220 / 230 / 240 V, 12 KW, 15 KVA, 50 - 60 Hz or
 AC 380 / 400 / 415 V, 12 KW, 15 KVA, 50 - 60 Hz
 for 3), 4)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
 Zertifizierungsstelle und internat. Angelegenheiten
 Certification Body and internat. Affairs

Date: 2022-04-13

Signature:



M. Ackermann