



Product Service

CERTIFICATE

No. Z10 090763 0004 Rev. 03

Holder of Certificate: **Schneider Electric Automation GmbH**
Schneiderplatz 1
97828 Marktheidenfeld
GERMANY

Certification Mark:



Product: **Safety-Related Programmable Systems**
Modular Safety Integrated Controller

Model(s): **Preventa XPSMCM**

Parameters:

Rated voltage:	24 Vdc $\pm 20\%$
Operating temperature:	-10 °C ... +55 °C
Storage temperature:	-20 °C ... +85 °C
Max. rating relay output:	230 VAC - 6A

The report SM106146C is a mandatory part of this certificate.

**Tested
according to:**

2006/42/EC
EN 61131-2:2007
EN ISO 13849-1:2023
EN IEC 61496-1:2020 (Type 4)
EN 61508-1:2010 (SIL3)
EN 61508-2:2010 (SIL3)
EN 61508-3:2010 (SIL3)
IEC 62061:2021 (maximum SIL 3)
EN 81-20:2020
EN 81-50:2020

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: SM106146C
Valid until: 2029-11-12
Date, 2026-01-12

(Gert Effenberger)