

**DUAL ROW SYSTEM (CEILING WITH CURTAIN DOOR)–STANDARD CEILING PANEL CONFIGURATION  
(TYPICAL 36 INCH AISLE WIDTH SHOWN FOR ILLUSTRATION)**



FRONT VIEW

**NOTES:**

1. COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
4. WEIGHT – REFER TO THE RESEPECTIVE SUBMITTALS.
5. OVER ALL WIDTH DIMENSION MAY VARY AS PER RACK WIDTH.
- △6. OVER ALL HEIGHT DIMENSION MAY VARY AS PER RACK HEIGHT. SHOWN TYPICAL ARRANGEMENT FOR 42U RACK.
- △7. DRAWING ABOVE SHOWN IS FOR TYPICAL CONFIGURATION.
8. RACKS ARE BAYED TOGETHER TIGHT AT 600mm SPACING, NOT MATCHING 24-INCH FLOOR TILES.  
LENGTH OF POD WILL CHANGE IF BAYED ON 24-INCH CENTERS TO MATCH FLOOR TILES.



RACK HEIGHT	
U	mm [inch]
42U	1991 [78.39]
45U	2124 [83.64]
48U	2258 [88.90]


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: ECO AISLE – DUAL ROW SYSTEM  
CEILING WITH CURTAIN DOOR  
STANDARD CEILING PANEL CONFIGURATION  
ASSEMBLY–FRONT VIEW

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 3

DWG NO:	EA-DRS-ASSY1	REV.	0
DRAWN BY:	K.NAGENDRA	06-MAY-16	FIRST ANGLE PROJ
ENGINEER:	NICK SCHWEISSGUTH	06-MAY-16	
APPROVED BY:	AARON GRAFF	06-MAY-16	



RIGHT SIDE VIEW

NOTES:

1. COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- Δ4. OVER ALL CONTAINMENT POD WIDTH DIMENSION MAY VARY AS PER THE COMPONENT SELECTED. REFER TO THE TABLE.
5. RACKS ARE BAYED TOGETHER TIGHT AT 600mm SPACING, NOT MATCHING 24-INCH FLOOR TILES. LENGTH OF POD WILL CHANGE IF BAYED ON 24-INCH CENTERS TO MATCH FLOOR TILES.



RACK DEPTH
mm [inch]
825 [32.480]
1070 [42.125]
1200 [47.244]


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE:  
ECO AISLE – DUAL ROW SYSTEM  
CEILING WITH CURTAIN DOOR  
STANDARD CEILING PANEL CONFIGURATION  
ASSEMBLY-SIDE VIEW

PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF 3

DWG NO:	EA-DRS-ASSY1	REV.	0
DRAWN BY:	K.NAGENDRA	06-MAY-16	FIRST ANGLE PROJ
ENGINEER:	NICK SCHWEISSGUTH	06-MAY-16	
APPROVED BY:	AARON GRAFF	06-MAY-16	



SKU No.	ACROSS AISLE DIMENSION
	mm [inch]
ACDC2100	694[27.32]
ACDC2101	
ACDC2102	999[39.33]
ACDC2103	
ACDC2104	1303[51.30]
ACDC2105	
ACDC2106	1608[63.31]
ACDC2107	

AISLE WIDTH	
Feet	mm [inch]
3	914.4 [36.0]
4	1219.2 [48.0]
5	1524.0 [60.0]
6	1828.8 [72.0]



- NOTES:**
1. COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL ELECTRICAL REGULATIONS.
  2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
  3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
  4. AISLE WIDTH MAY VARY AS PER THE REQUIREMENT. TABLE SHOWS STANDARD CONFIGURATION.
  5. RACKS ARE BAYED TOGETHER TIGHT AT 600mm SPACING, NOT MATCHING 24-INCH FLOOR TILES. LENGTH OF POD WILL CHANGE IF BAYED ON 24-INCH CENTERS TO MATCH FLOOR TILES.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



**TITLE:**  
ECO AISLE – DUAL ROW SYSTEM  
CEILING WITH CURTAIN DOOR  
STANDARD CEILING PANEL CONFIGURATION  
ASSEMBLY – TOP VIEW

**PROJECT:** SUBMITTAL DRAWINGS

<b>DWG NO:</b>	EA-DRS-ASSY1	<b>REV.</b>	0
<b>DRAWN BY:</b>	K.NAGENDRA	06-MAY-16	FIRST
<b>ENGINEER:</b>	NICK SCHWEISSGUTH	06-MAY-16	ANGLE
<b>APPROVED BY:</b>	AARON GRAFF	06-MAY-16	PROJ

TOP VIEW