



- NOTES:
- △ 1. THE CAPACITORS ARE ENERGY STORAGE FOR EPO WHEN NO OTHER SOURCE IS AVAILABLE
C1 = B41456-B7339-M = 33000µF (202-0333), C2 = B41456-B7339-M = 33000µF (202-0333)
 - △ 2. 15 CONDUCTOR IS SHIELDED TWISTED PAIR PROVIDED BY APC
 - 3. - - - - - IS EPO WIRING OPTIONAL.
 - △ 4. IF BATTERY CABINET FUSES ARE NOT PRESENT, THE TERMINALS WILL HAVE TO BE FITTED WITH JUMPERS.
 - △ 5. FOR BOARD PART NUMBERS CHECK THE LATEST REVISIONS.
 - 6. INSTALLATION MUST COMPLY WITH NATIONAL AND LOCAL CODES.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE:	SYMMETRA MW 400V, 3PH, 2x1600kW N+1 SYSTEM WIRING DIAGRAM	DWG NO:	SYMFM1600K1600HR2-WD	REV.	-
PROJECT:	SUBMITTAL DRAWINGS SHEET 1 OF 1	DRAWN:	BALAMURUGAN	PROJECTION	21/03/07
		CHECKED:	S WAGH		21/03/07
		ENGINEER:	S WAGH		21/03/07

APC
AMERICAN POWER CONVERSION
132 FAIRGROUNDS RD
WEST KINGSTON, RI 02892