



NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
3. USE ONLY 1-1.5sqmm COPPER WIRE FOR EPO CONNECTION.
- △ 4. APPLICABLE SKU : G35T15K3I2B2S, G35T15K3I2B4S, G35T15K3I3B4S, G35T15K3I4B4S, G35T20K3I2B2S, G35T20K3I2B4S, G35T20K3I3B4S, G35T20K3I4B4S, G35T30K3I3B4S, G35T30K3I4B4S, G35T40K3I4B4S
- △ 5. APPLICABLE SKU : G35TBXR2B6S/G35TBXR6B6S/G35TXR2B6S/G35TXR6B6S.
- △ 6. WHEN PINS 7 AND 8 ARE CLOSED, THE UPS CHARGES BATTERIES WITH A PRE-DEFINED PERCENTAGE(0-25-50-75-100%) OF MAXIMUM CHARGING POWER. TO BE USED IN GENERATOR APPLICATIONS, OR IF SPECIAL CODES REQUIRES CONTROL OF CHARGING.
- △ 7. MAXIMUM 4 XR BATTERY ENCLOSURES MAY BE USED WITH THE SYSTEM.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: MGE Galaxy 3500
 Input: 400/230V AC 3PH SINGLE/DUAL MAINS
 Output: 230V AC, 1PH
 15-40KVA
 SYSTEM WIRING DIAGRAM
 PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 1

DWG NO: G35T15K3I40-WD
 DRAWN: C KRISHNA
 ENGINEER: I KENNEDY
 APPROVED: CLARSEN

REV: 0
 ANGLE: N/A
 PROJECTION: N/A