



- NORMALLY OPEN EPO
- NORMALLY OPEN EPO RETURN
- NORMALLY CLOSED EPO
- NORMALLY CLOSED EPO RETURN
- +24V SELV SUPPLY
- SELV GROUND

NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
3. USE ONLY 1-1.5sqmm COPPER WIRE FOR EPO CONNECTION.
- △ 4. WHEN Q3 IS CLOSED, SIGNALS ARE FED BACK TO THE UPS CONTROLLER.
- △ 5. APPLICABLE SKU : G35T10KHS/G35T15KHS/G35T20KHS/G35T30KHS/G35T40KHS.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: MGE Galaxy 3500
Input: 400/230V AC 3PH SINGLE/DUAL MAINS
Output: 400/230V AC AND 400V AC 3PH
10-40kVA ONE MODULE WITHOUT BATTERIES
SYSTEM WIRING DIAGRAM

DWG NO: G35T10K40HNB-1MOD-WD

REV. 0

DRAWN: BALAMURUGAN 08-JUL-09

ENGINEER: I KENNEDY 08-JUL-09

APPROVED: CLARSEN 08-JUL-09

ANGLE

PROJECTION:

N/A

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 1