



**NOTES: UNLESS OTHERWISE SPECIFIED**

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS.
3. ALL EXTERNAL WIRING BY CUSTOMER.
4. POWER AND CONTROL CABLES SHALL BE IN SEPARATE CONDUITS.
5. CUSTOMER IS RESPONSIBLE FOR CONNECTING ALL SCHNEIDER ELECTRIC SUPPLIED CABLES.
- △6. UPSTREAM PROTECTIVE DEVICE REQUIRED. PROVIDED BY CUSTOMER.
- △7. ONE CABINET SHOWN. FOR UP TO FOUR (4) BATTERY CABINET CONNECTIONS, REFER TO DRAWINGS 90-174701-00 OR 90-174701-01.
- △8. SHOULD FEED FROM THE SAME SOURCE AS THE MBC.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



**ISOLATED REDUNDANT SINGLE LINE DIAGRAM**

TITLE:		DWG NO: 90-174781-00		REV. 0
GALAXY 5000 ISOLATED REDUNDANT SINGLE LINE DIAGRAM		DRAWN BY: BALAMURUGAN	31-MAR-10	ANGLE
PROJECT: SUBMITTAL DRAWINGS		ENGINEER: I. KENNEDY	16-DEC-08	PROJECTION
SHEET 1 OF 1		APPROVED BY: B.SHERIDAN/F.DIOSA	16-DEC-08	N.A.