



**NOTES:**

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
  2. PLEASE REFER TO PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
  3. DRAWING DEPICTS POWER SYSTEM CONNECTIONS AND IS NOT REPRESENTATIVE OF PHYSICAL LAYOUT. PLEASE REFER TO MECHANICAL DRAWINGS FOR MORE SPECIFIC PHYSICAL DATA.
- △4. MUST BE 4-WIRE + EQUIPMENT GROUND PROVIDED SOURCE.
- △5. ----- = CABLING PROVIDED BY OTHERS.
6. INPUT OVERCURRENT PROTECTION AND WIRING MUST BE INSTALLED FOR A FULLY RATED 20kW SYMMETRA, 3Ø. INPUT OVERCURRENT PROTECTION IS BASED ON 80% RATING ANY DEVIATION PLEASE CONTACT SCHNEIDER ELECTRIC.
  7. AC POWER CABLING IS 4-WIRE + EQUIPMENT GROUND AT 208VAC, 3Ø.
  - △8. OUTPUT DISTRIBUTION CIRCUIT BREAKERS ARE OPTIONAL AND ARE NOT PROVIDED WITH THE UNIT.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: InfraStruXure 20kW SYSTEM  
INPUT: 208VAC, SINGLE FEED  
OUTPUT: 208VAC, 20kW, N+1 w/ MBP  
SYSTEM SINGLE-LINE DIAGRAM

PROJECT: STD SUBMITTAL DRAWING SHEET: 1 OF 1

DWG NO:	<b>ISX20K20F-SD</b>	REV.	<b>1</b>
DRAWN:	C KRISHNA/S CUNHA	02-OCT-14	PROJ ANGLE
ENGINEER:	J RING/F DIOSA	21-MAR-12	N/A
APPROVED:	R HANSEN/E SILVA	21-MAR-12	