



NOTES:

1. PLEASE REFER TO APC INSTALLATION GUIDE.
- △2. MUST BE 3x380/400/415V TN-S/TN-C/IT/TT (PROVIDED BY OTHERS).
3. ----- = AC/DC CABLING PROVIDED BY OTHERS.
4. ALL AC POWER CABLING IS L1,L2,L3,N,PE.
- △5. DC CABLING SHOULD BE SEGREGATED FROM AC CABLING
SEE BATTERY INSTALLATION INFORMATION
6. UPS INPUT AND OUTPUT CABLES SHOULD BE SEGREGATED
7. POWER WIRING AND CONTROL WIRING SHOULD BE SEGREGATED
- △8. XR BATTERY CABINET CAN BE BAYED TO UPS. BAYING KIT HAS TO BE PURCHASED AS AN OPTION.
XR BATTERY CABINET IS ALSO AVAILABLE WITHOUT BREAKER, WITH DC FUSES ONLY
UP TO 4 XR BATTERY CABINETS CAN BE CONNECTED TO UPS TO EXTEND BACKUP TIME
- △9. SINGLE MAINS INSTALLATION IS A DEFAULT.
FOR DUAL MAINS OPTION REFER TO DRAWING# SUVT10KH2S-SD FOR DETAILS
10. OUTPUT OVERCURRENT PROTECTION MUST BE PROVIDED BY OTHERS.
RECOMMENDED OUTPUT BREAKER RATING 16A
11. INSTALLATION MUST COMPLY WITH NATIONAL AND LOCAL CODES.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.	TITLE: SMART-UPS VT INPUT: 3x380/400/415V SINGLE FEED OUTPUT: 3x380/400/415V 10kVA SYSTEM ONE LINE DIAGRAM		DWG NO: SUVT10KH1S-SD		REV. 2
	PROJECT: SUBMITTAL DRAWING		DRAWN: JAYAPRAKASH	11/10/05	PROJECTION ⊕
	SHEET 1 OF 1		CHECKED: M.SALOKHE	11/10/05	
			ENGINEER: S.WAGH	11/10/05	
			APC [®]		AMERICAN POWER CONVERSION 132 FAIRGROUNDS RD WEST KINGSTON, RI 02892