



NOTES:

1. PLEASE REFER TO APC INSTALLATION GUIDE.
- △ 2. SHALL BE L1, L2, L3, N, PE (PROVIDED BY OTHERS).
- △ 3. ----- = AC/DC CABLING (PROVIDED BY OTHERS).
4. ALL AC POWER CABLING IS L1, L2, L3, N, PE.
- △ 5. DC CABLING SHOULD BE SEGREGATED FROM SC CABLING. SEE BATTERY INSTALLATION INFORMATION.
6. UPS INPUT AND OUTPUT CABLES SHOULD BE SEGREGATED.
7. POWER WIRING AND CONTROL WIRING SHOULD BE SEGREGATED.
- △ 8. XR BATTERY CABINET CAN BE BAYED TO UPS. BAYING KIT SHALL BE PURCHASED AS AN OPTION. XR BATTERY CABINET IS ALSO AVAILABLE WITHOUT BREAKER, WITH DC FUSES ONLY. UP TO 4 XR BATTERY CABINETS CAN BE CONNECTED TO UPS TO EXTEND BACK UP TIME.
9. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
10. SEE PRODUCT DOCUMENTATION FOR FURTHER INFORMATION.
11. THIS DRAWING DEPICTS THE POWER SYSTEM CONNECTIONS AND IS NOT REPRESENTATIVE OF THE PHYSICAL LAYOUT. PLEASE REFER TO MECHANICAL DRAWINGS FOR PHYSICAL LAYOUT.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: SMART-UPS VT WITH MAINTENANCE BYPASS PANEL
 INPUT: 3x400/230V SINGLE MAINS
 OUTPUT: 3x3400/230V 10kVA
 SYSTEM ONE LINE

PROJECT: STD SUBMITTAL DRAWINGS SHEET 1 OF 1

DWG NO: SUVTPMBP10KH1S-SD REV. 2

DRAWN BY: V BUSH 15-APR-11

ENGINEER: B H NIELSEN 15-APR-11

APPROVED BY: C LARSEN 15-APR-11

PROJ ANGLE
 N.A.