



Ref. Certif. No.

CN30624-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

AC Contactors

Name and address of the applicant  
Nom et adresse du demandeur

Schneider Shanghai Industrial Control Co., Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Name and address of the manufacturer  
Nom et adresse du fabricant

SCHNEIDER ELECTRIC INDUSTRIES SAS  
31, rue Pierre Mendès France - 38050 Grenoble Cedex 9 - France

Name and address of the factory  
Nome et adresse de l'usine

SCHNEIDER ELECTRIC INDIA Pvt. Ltd  
Survey No.215, Village – Gagillapur Medak Road, Rangareddy  
District, Hyderabad – 500 043, (A.P.) India

Note: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)  
Marque de fabrique (si elle existe)

Schneider Electric

Model / Type Ref.  
Ref. De type

LC1E32..., LC1E38...

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)

The Original CB certificate No. is CN30624, dated 2014-06-04. The M1 certificate has been issued due to adding coil voltage 230V.

PUBLICATION

EDITION

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60947-4-1:2009(3rd Edition)+A1:2012, IEC 60947-1:2007(5th Edition)+A1:2010

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

00901-CB2013CQC-056522, 00901-CB2013CQC-056522-M1

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2015-09-29

Signature:

Wang Kejiao

Issued 2003-05  
China Quality Certification Centre  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666  
Fax: +86-10-83886282

website  
www.cqc.com.cn

CB 0033026



Ref. Certif. No.

CN30624-M1

LC1E32..., LC1E38...

Ui: 690V;

Ith:50A;

LC1E32...:

AC-3:AC220/230/380V/32A,400/415V/29A;

AC-4:AC220/230/380V/26.7A,400/415V/24.2A;

LC1E38...:

AC-3:AC220/230/380V/38A,400/415V/35A;

AC-4:AC220/230/380V/31.7A,400/415V/29.2A;

Us:AC24V, 36V, 48V, 110V, 220V, 240V, 380V, 415V, 440V 50Hz;

AC24V, 110V, 220V, 380V, 440V 60Hz;

AC24V, 48V, 110V, 220V, 230V, 380V 50/60Hz;

3P;

IP20;

Auxiliary Circuits (body contact):

Ith:10A;

AC-15:AC380V/1.3A, 660V/0.75A;

DC-13:DC220V/0.3A;

1NO, 1NC

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2015-09-29

Signature:

Wang Kejiao