

AENOR

AENOR Product Certificate Low Voltage Material



030/002229

AENOR certifies that the organization

SCHNEIDER ELECTRIC ESPAÑA, S.A.

registered office CL BAC DE RODA, 52 EDIFICIO A 08019 BARCELONA (España)

supplies Circuit-Breakers for overcurrent protection for household and similar installation

in compliance with UNE-EN 60898-1:2004 (EN 60898-1:2003; EN 60898-1:2003 CORR:2004)
UNE-EN 60898-1:2004/A11:2006 (EN 60898-1:2003/A11:2005)
UNE-EN 60898-1:2004/A1:2005 (EN 60898-1:2003/A1:2004)
UNE-EN 60898-1:2004/A12:2009 (EN 60898-1:2003/A12:2008)
UNE-EN 60898-1:2004/A13:2013 (EN 60898-1:2003/A13:2012)

References Specified in Annex to the Certificate

Production site PLOVDIV PLANT 4202 RADINOVO (Bulgaria)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 030.15.

This certificate supersedes 030/002229, dated 2010-12-28

First issued on 2010-12-28
Modified on 2017-03-03
Validity date 2022-03-03

Avelino BRITO
General Manager

Original Electrónico

AENOR

AENOR Product Certificate Low Voltage Material

030/002229

Annex to Certificate

Trade mark: Schneider Electric

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
A9K24101	1P	230 V-	1 A	6000 A	6000 A	3	C
A9K24102	1P	230 V-	2 A	6000 A	6000 A	3	C
A9K24103	1P	230 V-	3 A	6000 A	6000 A	3	C
A9K24104	1P	230 V-	4 A	6000 A	6000 A	3	C
A9K24140	1P	230 V-	40 A	6000 A	6000 A	3	C
A9K24201	2P	400 V-	1 A	6000 A	6000 A	3	C
A9K24202	2P	400 V-	2 A	6000 A	6000 A	3	C
A9K24203	2P	400 V-	3 A	6000 A	6000 A	3	C
A9K24204	2P	400 V-	4 A	6000 A	6000 A	3	C
A9K24240	2P	400 V-	40 A	6000 A	6000 A	3	C
A9K24601	1P+N	230 V-	1 A	6000 A	6000 A	3	C
A9K24602	1P+N	230 V-	2 A	6000 A	6000 A	3	C
A9K24603	1P+N	230 V-	3 A	6000 A	6000 A	3	C
A9K24604	1P+N	230 V-	4 A	6000 A	6000 A	3	C
A9K24640	1P+N	230 V-	40 A	6000 A	6000 A	3	C

First issued on 2010-12-28
Modified on 2017-03-03
Validity date 2022-03-03

Original Electrónico

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com