

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1110409

**Product:** Lightning Current Arrester Type 1 and Surge Arrester Type 2

**Type:** PRF1 12,5r 1P+N ref 16632,  
PRF1 12,5r 3P ref 16633,  
PRF1 12,5r 3P+N ref 16634

**Rating:** L-N:  $U_c=350$  V AC,  $I_{imp}=12,5$  kA,  $I_{max}=50$  kA,  $I_n=25$  kA,  
N-PE:  $U_c=255$  V AC,  $I_{imp}=50$  kA,  $I_{max}=50$  kA,  $I_n=25$  kA,  
IP40/20

**Ordering firm:** Schneider-Electric SAS  
31 rue Pierre Mendès France, Eybens, F-38050 Grenoble Cedex 9, France

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem, Czech Republic

**Trade mark:** Schneider-Electric

The test results are stated in the test-report No.: 003647-01/01 of: 08.11.2010

A sample of the product was found to be in conformity with:

ČSN EN 61643-11:03+A11:07

cl.7.2,7.3,7.4,7.7.5,7.5.2,7.5.3,7.6.4/7.7.1,7.6.5/7.6.6/7.7.1,7.7.2,7.7.3,7.7.6,7.7.4,7.9.2.1,7.9.7,7.9.8,7.9.9,7.9.3,7.9.5.2,7.9.4,7.9.6,6.2.12.

The validity of the certificate is limited to: 30.11.2013

21.4.2011

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



101527-01